

FreshFlow Beverages Pvt. Ltd.

FreshFlow Bottling Plant - Pune Production Facility
FSSAI: 10012022000345 | ISO 22000:2018 / ISO 14001:2015

INCIDENT REPORT

Incident Report: Safety (Near Miss)

Slip/trip hazard observed

Equipment ID: P103

Document Number: INC-033
Revision: Final
Classification: CONFIDENTIAL - INTERNAL USE ONLY
Prepared by: Engineering / QA Department
Approved by: Plant Manager

1. Incident Overview

1.1 Basic Information

Parameter	Value
Incident ID	INC-033
Type	Safety (Near Miss)
Date & Time	2023-10-06 11:11
Location / Department	Water Treatment
Associated Asset	P103
Asset Name	P103 Water Transfer Pump
Reported By	Employee 15 (Operator)
Investigator	Rajesh Kulkarni (Plant Manager)

2. Description of Event

On 2023-10-06 at 11:11, an incident classified as 'Safety (Near Miss)' occurred. The primary observation was: Water pooling on floor near filler.. The area was secured by the shift supervisor immediately after the event.

The incident occurred during operation/maintenance of equipment P103 (P103 Water Transfer Pump). Refer to equipment manual MAN-P103-001 for technical context.

3. Immediate Actions Taken

- Secured the area and stopped relevant machinery (if applicable).
- Administered first aid / contained spill / quarantined product (as per incident type).
- Notified the Plant Manager and EHS/QC department.
- Initial mitigation applied: Install additional floor drain; immediate clean-up.

4. Root Cause Analysis (Summary)

A formal investigation was conducted. The preliminary root causes identified include inadequate risk perception, equipment failure, or procedural deviation. (A full RCA report is generated separately for critical incidents).

5. Corrective and Preventive Actions (CAPA)

Action Description	Owner	Target Date	Status
Install additional floor drain; immediate clean-up.	Rajesh Kulkarni	2023-10-13	Closed
Review and update relevant SOP/RA	Employee 15	2023-10-20	In Progress
Conduct toolbox talk with shift team	Shift Supervisor	2023-10-08	Closed

6. Signatures & Closure

Report Prepared By: Employee 15
Date: 2023-10-07

Approved By: Rajesh Kulkarni
Date: 2023-10-08