

FreshFlow Beverages Pvt. Ltd.

FreshFlow Bottling Plant - Pune Production Facility
FSSAI: 10012022000345 | ISO 22000:2018 / ISO 14001:2015

INSPECTION REPORT

Inspection Report: Equipment Condition Audit

Department: Utilities

Document Number: INSP-211
Revision: Final
Classification: CONFIDENTIAL - INTERNAL USE ONLY
Prepared by: Engineering / QA Department
Approved by: Plant Manager

1. Inspection Details

1.1 Overview

Parameter	Value
Inspection ID	INSP-211
Type	Equipment Condition Audit
Date & Time	2023-04-03 10:42
Location / Department	Utilities
Inspector	Farah Shaikh (Food Safety Officer)
Overall Score / Result	Pass (with observations)

2. Scope & Methodology

This report covers the Equipment Condition Audit conducted in the Utilities department. The inspection utilized standard FreshFlow checklists and visual observations. The objective is to ensure compliance with FSSAI, ISO 22000, and internal corporate standards.

3. Detailed Observations

Area/Equipment	Observation	Status	Priority
General Area	Vibration seems excessive.	Failed	High
General Area	Minor oil weep from gearbox.	Failed	Medium
General Area	Panel door loose.	Failed	High
General Area	Minor oil weep from gearbox.	Failed	Medium
UPS104	No visible leaks.	Passed	Low
CP103	Vibration seems excessive.	Failed	High

4. Recommendations & Corrective Actions

All 'Failed' or 'Requires Attention' items must be entered into the CMMS or CAPA system within 24 hours of this report. Shift Supervisors are responsible for immediate mitigations.

5. Signatures

Inspected By: Farah Shaikh
Date: 2023-04-03