

FreshFlow Beverages Pvt. Ltd.

FreshFlow Bottling Plant - Pune Production Facility
FSSAI: 10012022000345 | ISO 22000:2018 / ISO 14001:2015

INCIDENT REPORT

Incident Report: Environmental (Spill/Release)

CO2 release

Equipment ID: TK101

Document Number: INC-152
Revision: Final
Classification: CONFIDENTIAL - INTERNAL USE ONLY
Prepared by: Engineering / QA Department
Approved by: Plant Manager

1. Incident Overview

1.1 Basic Information

Parameter	Value
Incident ID	INC-152
Type	Environmental (Spill/Release)
Date & Time	2023-05-16 09:45
Location / Department	Water Treatment
Associated Asset	TK101
Asset Name	TK101 Water Storage Tank
Reported By	Employee 20 (Engineer)
Investigator	Rajesh Kulkarni (Plant Manager)

2. Description of Event

On 2023-05-16 at 09:45, an incident classified as 'Environmental (Spill/Release)' occurred. The primary observation was: Safety valve lifted on CO2 tank.. The area was secured by the shift supervisor immediately after the event.

The incident occurred during operation/maintenance of equipment TK101 (TK101 Water Storage Tank). Refer to equipment manual MAN-TK101-001 for technical context.

3. Immediate Actions Taken

- Secured the area and stopped relevant machinery (if applicable).
- Administered first aid / contained spill / quarantined product (as per incident type).
- Notified the Plant Manager and EHS/QC department.
- Initial mitigation applied: Area evacuated. Adjust regulator and replace safety valve.

4. Root Cause Analysis (Summary)

A formal investigation was conducted. The preliminary root causes identified include inadequate risk perception, equipment failure, or procedural deviation. (A full RCA report is generated separately for critical incidents).

5. Corrective and Preventive Actions (CAPA)

Action Description	Owner	Target Date	Status
Area evacuated. Adjust regulator and replace safety val	Rajesh Kulkarni	2023-05-23	Closed
Review and update relevant SOP/RA	Employee 20	2023-05-30	In Progress
Conduct toolbox talk with shift team	Shift Supervisor	2023-05-18	Closed

6. Signatures & Closure

Report Prepared By: Employee 20
Date: 2023-05-17

Approved By: Rajesh Kulkarni
Date: 2023-05-18