Containerized Office Unit 6100 mm x 2440 (L x W)		
	Number of Ventilators	2 nos.
	Number of windows	2 nos.
	Inside wall panelling material	Prelaminated MDF board
	Inside wall panelling thickness (in mm)	6 mm
	Inside flooring	Single layer
	Inside flooring Base Layer	Wooden Vinyl board
	Thickness of Inside flooring base layer (in mm)	18 mm
	Inside flooring top layer	Vinyl sheet
	Thickness of Inside flooring top layer (in mm)	1 mm
	Ceiling	MDF sheet 6 mm
	Provision of insulation (Ceiling)	50mm thick Glass wool insulation with chicken mesh (density of Glass wool 16kg/m3)
	Provision of Fixing air conditioner (AC NOT PART OF SUPPLY)	For one split AC
	Provision of fixing Ceiling fan (FAN NOT PART OF SUPPLY)	2 nos.
	Provision for Ceiling light	3
	Suitable provision of ELECTRICAL WIRING & FITMENTS	YES
	Provision of lifting and shifting	Yes
DIMENSION	Length of Unit	6100 mm
	Width of unit	2440 mm
	Height of Unit	2590 mm
	Height of External door	1980 mm
	Width of External door	915 mm
	Height of ventilation	610 mm
	Width of ventilation	610 mm
	Height of window	915 mm
	Width of window	915 mm
UNIT LIFTING / SHIFTING	Bottom frame	Made up of 2 mm thick M.S. Sheet – Four corner pst made up of 2.8 mm thick (to facilitate transportation, lifting & shifting) – Base frame C- Channel made up of minimum 2 mm thick M.S. Sheet
	Hooks material	Specially formed hooks made up of minimum 6 mm thick plate
MATERIAL OF WALL PANELS	Wall panel Insulation	Gap between wall skins to be filled with 50mm thick mineral wool (density 40kg/m3) insulation
	Panel Strengthened On all four sides	By 'W' shaped pre-profiled steel section made from 0.63 GI steel sheet / coil
	Wall panel(lengthwise) Interlocking	By using cold-formed rectangular hollow steel section of size 50 mm X 25 mm X 1.25 mm
	Concealing of Wall corners	With corner angle of 125 mm X 125 mm X 1.25 mm made from GI steel sheet / Coil
	Concealing of Top of walls	With 'U' shaped top track of size 52.5 mm X 35 mm X 1.25 mm made from GI steel sheet / coil
	Sellers are free to adopt higher sizes/reinforcement	For better fitment or mating of components or for improved stability
	Type of Roof	Self draining type
	Roof made up of	Galvanised corrugated sheets of 0.63 mm thickness conforming to IS 277/Latest having min. 275 gsm galvanising

ROOF AND ROOF FRAME WORK	Roof laid over on	Frame work of trusses - columns and purlins fixed using suitable fasteners like 'J' hooks with bitumen washers and nuts/bolts
	Size of Ridge cover to be fixed on top junction of roof of same material as Roof	225 mm X 225 mm X 0.63 mm
	Column to be welded	With 5 mm thick MS end plate and to be fixed to the foundation bolts through this plate
	To fix Trusses / purlins	Using 5 mm thick MS end plates and 10 mm nuts and bolts
	Trusses and Purlin made up of	Rectangular hollow sections of size 66 mm X 33 mm X 2.9 mm conforming to IS 4923/Latest duly ISI marked
	Truss columns made up of	Rectangular hollow steel sections of size 96 mm X 48 mm X 3.2mm conforming to IS 4923/Latest duly ISI marked
DOOR-WINDOWS AND VENTILATORS	Frame material of windows/ventilators	Made from pressed steel using CR steel of size 75 mm X 45 mm X 1.5 mm (thickness) conforming to IS 513/Latest
	Hinges for windows	6 Nos. 75 mm MS butt hinges welded on to the frame
	Hinges for ventilators	2 Nos. 75 mm MS butt hinges welded on to the frame
	Grills for Windows/Ventilators	Made from MS square bar of 8 mm having equal spacing of 125 mm
	Shutter material for windows/ventilators	Made out of steel rectangular hollow box profile of 1.25 mm thick
	Each window shutter consist of	MS oxidized handle of 150 mm - 2 Nos. MS oxidized tower bulls of 100 mm and 1 No. window stay
	Each ventilator shutter(Internal) consist of	1 No. stay hook
	Glass sheet for windows/ventilators	4 mm thickness to be fixed using glass putty
	Main door	MS doors standard hatchbolt fitted inside and outside
	Rainguard provision for Window	Yes
	Rainguard provision for door	Yes
ELECTRICAL WIRING AND FITMENTS	Type of electrical wiring	Concealed type
	Electrical points/sockets/fan regulators/gang way boxes standards	ISI mark
	Main switch board	Comprising of SP/DP MCBs to be supplied in addition
	Cables and PVC conduit	Adequate quantity to be provided
	Electrical installation/completeness	Seller is fully responsible for wiring etc. (except light fittings)
COLOUR AND FINISH	Corrugated GI sheets and ridge cover	have a min. galvanizing coating of 275 gsm
	Other GI profiles	have a min. galvanizing coating of 120 gsm
	MS steel members	supplied with one coat of red oxide primer coating
	Internal wall panels	one coat of cement primer and two coats of white oil bound distemper
	External wall panels	Antitrust treatment with Red oxide Primer and finished with two coats of enamel Hi-Gloss paint

Specification	Value
3. Wall panel	Wall panel (lengthwise) Interlocking: By using cold formed rectangular hollow steel section of size 50 mm x25 mmx 1.25 mm. Panel Strengthened On all four sides: By W shaped pre-profiled steel section made from 0.63 GI steel sheet/coil.
4. Concealing	Concealing of Wall corners: With corner angle of 125 mm x125 mm x1.25 mm made from GI steel sheet/coil. Concealing of Top of walls: With U shaped top track of size 52.5 mm x 35 mm x 1.25 mm, made from GI steel sheet/coil
5. Windows/ventilators	Frame material of windows/ventilators: Made form pressed steel using CR steel of size 75 mm x 45 mm x 1.5 mm (thickness). Grills for windows/ventilators: Made form MS square bar of 8 mm having equal spacing of 125 mm. Glass sheet for windows/ventilators: 4 mm thickness to be fixed using glass putty