

UP Assembly Security Assessment - Confidential

Language: EN | Category: COMMITTEE_REPORT | Security: CONFIDENTIAL | State: UP

UTTAR PRADESH VIDHAN SABHA

SECURITY AND PROTOCOL ASSESSMENT

STRICTLY CONFIDENTIAL - SPEAKER'S OFFICE ONLY

Reference: SPK/SEC/2025/034

Subject: Comprehensive Security Review of Legislative Assembly Complex

1. CURRENT SECURITY INFRASTRUCTURE

- 1.1 CCTV Coverage: 847 cameras across the complex, 23 non-functional
- 1.2 Access Control: Biometric entry at 12 of 18 entry points
- 1.3 Personnel: 340 security staff in 3 shifts

2. VULNERABILITIES IDENTIFIED

- 2.1 Service entrance on North Wing lacks biometric verification
- 2.2 Underground parking area has 4 blind spots in camera coverage
- 2.3 VIP gallery access protocol allows unvetted visitors with MLA escort
- 2.4 Emergency evacuation routes 3 and 5 partially obstructed by stored materials

3. CYBER SECURITY

- 3.1 Assembly Wi-Fi network penetration test: 2 of 6 access points vulnerable
- 3.2 Document management system running outdated version with known CVEs
- 3.3 12 workstations without endpoint protection

4. RECOMMENDED ACTIONS (Priority Order)

- 4.1 IMMEDIATE: Repair 23 non-functional CCTV cameras (Est: Rs. 15 Lakh)
- 4.2 IMMEDIATE: Install biometric at remaining 6 entry points (Est: Rs. 45 Lakh)
- 4.3 HIGH: Clear evacuation routes and conduct mock drill
- 4.4 HIGH: Update document management system and patch all workstations
- 4.5 MEDIUM: Revise VIP gallery access protocol with mandatory pre-registration

This document is classified under Speaker's discretion. Unauthorized reproduction or distribution is a breach of privilege.