

Form 7

Form Details

Index ID	Detail	Values	Control Measures
7.01	Are reasonable measures taken to prevent fires of electrical origin?	Yes	N/A
7.02	Are fixed installations periodically inspected and tested?	No	Test 01
7.03	Is portable appliance testing carried out?	Yes	N/A
7.04	Is there suitable control over the use of personal electrical appliances?	Yes	N/A
7.05	Is there suitable limitation of trailing leads and adapters?	Yes	N/A
8.01	Are reasonable measures taken to prevent fires as a result of smoking?	Yes	N/A
8.03	Is smoking prohibited in the building?	No	Test 01
8.04	Is smoking prohibited in appropriate areas?	Yes	N/A
8.05	Are there suitable arrangements for those who wish to smoke?	No	Test 01
8.06	Did the smoking policy appear to be observed at the time of inspection?	Yes	N/A
9.01	Does basic security against arson by outsiders appear reasonable?	No	Test 01
9.02	Is there an absence of unnecessary fire load in close proximity to the premises or available for ignition by outsiders?	Yes	N/A
10.01	Is there satisfactory control over the use of portable heaters?	No	Test 01
10.02	Are fixed heating and ventilation installations subject to regular maintenance?	Yes	N/A
11.01	Are reasonable measures taken to prevent fires as a result of cooking?	No	Test 01
11.02	Are filters cleaned or changed and ductwork cleaned regularly?	Yes	N/A
12.01	Does the building have a lightning protection system?	Yes	N/A