

REGULATORY REFORM (FIRE SAFETY) ORDER 2005 FIRE RISK ASSESSMENT

Company Name

Address1

Address2

Address3

Address4

Responsible person (e.g. employer) or person having control of premises:	
Address of premises:	
Person(s) consulted:	
Assessor:	
Assessors statement:	The purpose of this PAS 79-2:2020 (Annex A) Housing risk report is to provide a non-invasive assessment of the risk to life from fire in these premises, and, where appropriate, to make recommendations to ensure compliance with fire safety legislation. This report does not address the risk to property or business continuity from fire. I certify that to the best of my knowledge, the information contained in this fire risk assessment is correct, based on information provided at the time the assessment was undertaken.
Report validated by:	
Date of fire risk assessment:	
Date of previous fire risk assessment:	
Suggested date for review:	
Fire Risk Assessment Review:	This fire risk assessment should be reviewed by a competent person by the date indicated above or at such earlier time as there is reason to suspect that it is no longer valid, or there has been significant change in the matters to which it relates, or if a fire occurs.
Report compliance:	This report is intended to assist you in compliance with Article 9 of the Regulatory Reform (Fire Safety) Order 2005 which requires that a fire risk assessment be carried out.

1.00	THE PREMISES (Clause 12)	
1.01	Number of floors at ground level and above:	
	Number of floors entirely below ground level:	
	Floors on which car parking is provided:	
1.02	Number of flats:	
	Approximate gross floor area:	m ² .
1.03	Brief details of construction and approximate age of building: <i>Prompt: Give a detailed & clear overview of the building so it can be visualised including building age, how many internal/external stairways, lifts and final exits.</i>	
1.04	Occupancy: <i>e.g. blocks of flats, sheltered housing, extra care housing, supported housing or HMOs.</i>	
2.00	THE OCCUPANTS (Clause 12)	
2.01	Approximate maximum number of employees at any one time:	
2.02	Approximate maximum number of residents and visitors at any one time:	
3.00	OCCUPANTS ESPECIALLY AT RISK FROM FIRE (Clause 12)	
3.01	Sleeping occupants	
3.02	Occupants in remote areas and lone workers:	
3.03	Others:	
3.04	Disabled occupants (if known):	
4.00	FIRE LOSS EXPERIENCE	
4.01	Fires in the past:	
4.02	Cost of past fire losses:	

5.00	OTHER RELEVANT INFORMATION	
5.01	Detail here if required: <i>Prompt: Alarm system type, sprinkler, AOVs etc...</i>	
6.00	RELEVANT FIRE SAFETY LEGISLATION	
6.01	The following fire safety legislation applies to these premises:	<i>Regulatory Reform (Fire Safety) Order 2005, The Fire Safety Act 2021, The Fire Safety Regulations (England) 2022 and Building Safety Act 2022. Or Fire (Scotland) Act 2005 and The Fire Safety (Scotland) Regulations 2006. ammend as required.</i>
6.02	The above legislation is enforced by:	<i>***** Fire & Rescue Service/ LFB etc...</i>
6.03	Other legislation that makes significant requirements for fire precautions in these premises:	<i>Other Legislation if applicable e.g) The Housing Act 2004</i>
6.04	The other legislation referred to above is enforced by:	<i>Local Authority etc...</i>
6.05	Is there an alterations notice in force?	
6.06	Relevant information and deficiencies observed:	
6.07	Other information if required: <i>Prompt: This text area can be used to add any other detail if required.</i>	<i>#Add referenced fire guides here# #Add fire evacuation method here#</i>

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
7.00	ELECTRONIC SOURCES OF IGNITION <i>(Clause 13 and Annex B)</i>				
7.01	Are reasonable measures taken to prevent fires of electrical origin?	✓	✓	✓	Maintain safe separation distance of ½ metre between appliance and combustible materials. Enclose electrical intake in 30 or 60 minute fire resisting enclosure. Prohibit any combustible or flammable storage in electrical intake room. Ensure that sources of heat do not arise from faulty or overloaded electrical equipment. Ensure that all electrical fuses and circuit breakers etc. of the correct rating and suitable for the purpose. Switch equipment off at the end of the working day.
7.02	More specifically:				
7.02 a)	Are fixed installations periodically inspected and tested?				Introduce a programme of inspection and tests by a competent electrician to the current EICR certificate.
7.02 b)	Is portable appliance testing carried out?				Have workplace portable electrical appliances tested by a competent person.
	Observations: <i>(PAS 79: 2020 states all observations should be small font size and italic)</i>				
8.00	SMOKING <i>(Clause 13 and Annex B)</i>				
8.01	Are reasonable measures taken to prevent fires as a result of smoking?				Introduce a safe smoking policy in designated smoking areas and enforce prohibiting smoking elsewhere.
8.02	More specifically:				
8.02 a)	Is smoking prohibited in appropriate areas?				Introduce a safe smoking policy in designated smoking areas and enforce prohibiting smoking elsewhere.
8.02 b)	Are there suitable arrangements for those who wish to smoke?				Introduce a safe smoking policy in designated smoking areas and enforce prohibiting smoking elsewhere.
8.02 c)	Did the smoking policy appear to be observed at the time of inspection?				Introduce a safe smoking policy in designated smoking areas and enforce prohibiting smoking elsewhere.
8.02 d)	Are "No smoking" signs provided in the common areas?				Add "No smoking" signage at main entrance and other areas if required.
	Observations: <i>(PAS 79: 2020 states all observations should be small font size and italic)</i>				<i>e.g.) There were no signs of covert smoking during the FRA site visit and smoking is not allowed in communal areas.</i>
9.00	ARSON <i>(Clause 13 and Annex B)</i>				
9.01	Does basic security against arson by outsiders appear reasonable?				Have a security specialist advise on additional precautions to avoid the risk of arson.

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
9.02	Is there an absence of unnecessary fire load in close proximity to the premises or available for ignition by outsiders?				Remove or relocate any fire load in close proximity to the premises and control access for ignition by outsiders.
	Observations:				<i>e.g) If there are low concerns for potential Arson risk, add a clarification statement here.</i>
10.00	PORTABLE HEATERS, HEATING AND VENTILATION SYSTEMS <i>(Clause 13 and Annex B)</i>				
10.01	Is there satisfactory control over the use of portable heaters?				Ban the use of portable heaters in the workplace and adjust fixed heating accordingly.
10.02	Are fixed heating and ventilation installations subject to regular maintenance?				Arrange for heating and ventilation system to be maintained by a competent contractor.
	Observations:				
11.00	COOKING <i>(Clause 13 and Annex B)</i>				
11.01	Are reasonable measures taken to prevent fires as a result of cooking?				Maintain safe separation distance between appliances and flammable/combustible materials. Introduce safe working practices.
	Observations:				
12.00	LIGHTNING <i>(Clause 13 and Annex B)</i>				
12.01	Does the building have a lightning protection system?				Provide suitable lightning protection system to building in accordance with BS EN 62305-1:2011.
	Observations:				
13.00	HOUSEKEEPING <i>(Clause 13 and Annex B)</i>				
13.01	Is the overall standard of housekeeping adequate?				Ensure a programme is introduced to improve housekeeping.
13.02	More specifically:				
13.02 a)	Do combustible materials appear to be separated from ignition sources?				Maintain safe separation distance of ½ metre between appliance and combustible storage.
13.02 b)	Is unnecessary accumulation or inappropriate storage of combustible materials or waste				Remove and manage unnecessary waste or storage.
13.02 c)	Are gas and electricity intake/meter cupboards adequately secured and kept clear of combustible materials?				Manage plant area access and inform staff and/or residents that they must be kept clear at all times due to the likelihood of ignition.

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
	Observations:				
14.00	HAZARDS INTRODUCED BY OUTSIDE CONTRACTORS AND BUILDING WORKS <i>(Clause 13 and Annex B)</i>				
14.01	Is there satisfactory control over works carried out in the building?				Impose appropriate fire safety conditions on outside contractors.
	Observations:				
15.00	DANGEROUS SUBSTANCES <i>(Clause 13)</i>				
15.01	Are the general fire precautions adequate to address the hazards associated with dangerous substances used or stored within the premises?				Reduce the quantity of dangerous substances to a minimum. Manage out collation of any dangerous substances.
	Observations:				
16.00	OTHER SIGNIFICANT FIRE HAZARDS THAT WARRANT CONSIDERATION				
16.01	Hazards:				List and detail any other significant hazards here:
	Observations:				

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
17.00	MEANS OF ESCAPE <i>(Clause 15c) and Annex C)</i>				
17.01	Is the design and maintenance of the means of escape considered adequate?	✓	✓	✓	Improve the means of escape in as follows:
17.02	More Specifically:				
17.02 a)	Are there reasonable distances of travel:				
17.02 a1)	Where there is escape in a single direction?				Provide a pass door in the following locations: #add locations#. Provide external fire escape in the following location # add location#. Provide an additional exit to the escape corridor from the inner room #add location#.
17.02 a2)	Where there are alternative means of escape?				Provide external fire escape in the following location # add location#. Provide an additional exit to the escape corridor from the inner room #add location#.
17.02 b)	Is there adequate provision of exits?				Provide additional escape exits in the following locations #add location#.
17.02 c)	Do fire exits open in the direction of escape, where necessary?				Re-hang and recess the door to #add location# to open in the direction of escape.
17.02 d)	Are the arrangements provided for securing exits satisfactory?				Reduce the securing devices on final exit doors to a single device provided with a suitable sign on how to operate.
17.02 e)	Is the fire-resisting construction (including any glazing) protecting escape routes and staircases of a suitable standard and maintained in sound condition?				Repair or replace damaged partitions to the required fire resisting rating including 1.8m (England & Wales) or 2.0m (Scotland) rule to external staircases.
17.02 f)	Is the fire resistance of doors to staircases and the common areas considered adequate, and are the doors maintained in sound condition?				The following staircase and common area fire doors require attention: Fire door maintenance or installations should be actioned by a 3rd party accredited and competent contractor and must comply to the manufacturer recommendations or BS 8214:2016.
17.02 g)	Are suitable self closing devices fitted to fire doors in the common areas?				Install BS EN 1154 self closing devices to the following common area fire doors: Installations and maintenance should be actioned by a 3rd party accredited and competent contractor and must comply to the manufacturer recommendations or BS 8214:2016.
17.02 h)	Is the fire resistance of doors to meter cupboards/store rooms/plant rooms in common areas considered adequate, and are they adequately secured and/or fitted with suitable self-closing devices?				The following common area plant room fire doors require attention: Fire door maintenance or installations should be actioned by a 3rd party accredited and competent contractor and must comply to the manufacturer recommendations or BS 8214:2016.

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
17.02 i)	Is the fire resistance of flat entrance doors considered adequate, and are the doors maintained in sound condition?				The following flat entrance fire doors require attention: Fire door maintenance or installations should be actioned by a 3rd party accredited and competent contractor and must comply to the manufacturer recommendations or BS 8214:2016.
17.02 j)	Are suitable self closing devices fitted to flat entrance fire doors and, where fitted, maintained in good working order?				Install BS EN 1154 self closing devices to the following flat entrance fire doors: Installations and maintenance should be actioned by a 3rd party accredited and competent contractor and must comply to the manufacturer recommendations or BS 8214:2016.
17.02 k)	Are there adequate smoke control provisions to protect the common escape routes, where necessary?				Consider advice from a competent smoke control engineer.
17.02 l)	Are all escape routes clear of obstructions?				Clear internal or external storage.
17.02 m)	Are all fire exits easily and immediately openable?				Remove one of the two securing devices from the final exit door from the #add location#. Install suitable interlocks on doors normally kept close for security reasons in the following locations: #add locations# . Provide a panic bolt/latch and appropriate sign on the final exit door from #add location#.
17.02 n)	Are there reasonable arrangements for means of escape for disabled people?				Improve escape options for disabled people. Move residence with mobility issues to the ground floor. Provide PEEPs or GEEPs where necessary.
	Observations:				
18.00	MEASURES TO LIMIT FIRE SPREAD AND DEVELOPMENT <i>(Clause 15g)</i>				
18.01	Is it considered that there is/are:				
18.01 a)	Adequate levels of compartmentation between floors and between flats and the common escape routes?				Action a compartmentation survey by a competent contractor.
18.01 b)	Reasonable limitation of linings that may promote fire spread?				Remove the combustible construction and replace it with fire-resisting or non-combustible alternatives.
18.01 c)	As far as can be reasonably be ascertained, reasonable fire separation within any roof space?				Have a roof compartmentation survey actioned by a competent contractor.
18.01 d)	Adequately fire protected service risers and/or ducts in common areas, that will restrict the spread of fire and smoke?				Have service risers and/or ducts inspected by a competent contractor.

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
18.02	As far as can be reasonably be ascertained, are fire dampers provided necessary to protect critical means of escape against passage of fire, smoke and products of combustion in the early stages of a fire?				Have an invasive survey actioned by a fire damper competent specialist.
	Observations:				
19.00	EMERGENCY ESCAPE LIGHTING (Clause 15e)				
19.01	Has a reasonable standard of emergency escape lighting system been provided?				Provide emergency lighting to illuminate internal and external escape routes and points of emphasis.
	Observations:				
20.00	FIRE SAFETY SIGNS AND NOTICES (Clause 15d)				
20.01	Is there a reasonable standard of fire safety signs and notices?				Provide green moving person signs with appropriate directional arrows to indicate the secondary escape routes in the following locations: #add locations#.
	Observations:				
21.00	MEANS OF GIVING WARNING IN CASE OF FIRE (Clause 15b)				
21.01	Is a reasonable fire detection and fire alarm system provided in common areas, where necessary?				See <i>Sleeping Accommodation Home Office Fire guide P57</i> for recommended minimum fire alarm standards. Install an electrical fire alarm system conforming to BS 5839. Provide additional fire alarm call points linked into the existing system in the following locations: #add location#
21.02	If there is a communal fire detection and fire alarm system, does it extend into the dwellings?				Actions required:
21.03	Where appropriate, has a fire alarm zone plan been provided?				Provide a fire alarm zone plan of the system adjacent to the main fire control panel.
21.04	Where appropriate, are there adequate arrangements for silencing and resetting an alarm condition?				Consider how alarms will be reset when required, especially in a non staffed premises.
	Observations:				
22.00	MANUAL FIRE EXTINGUISHING APPLIANCES (Clause 15f)				

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
22.01	Is there reasonable provision of manual fire extinguishing appliances?				<i>Are extinguishers required in common areas?</i> Replace the non standard fire extinguishers with BS/LPC approved extinguishers in the following locations.
22.02	Are all fire extinguishing appliances readily accessible?				Remove obstructions in the following places:
	Observations:				
23.00	RELEVANT AUTOMATIC FIRE EXTINGUISHING SYSTEMS <i>(Clause 15h)</i>				
23.01	Type of fixed system(s):				
23.01 a)	Sprinkler system?				Install sprinkler system if required and reasonably practicable due to life risk.
23.01 b)	Misting system?				Install misting system if required and reasonably practicable due to life risk.
	Observations: <i>(List fixed systems)</i>				<i>Sprinkler system type: Misting system type:</i>
24.00	OTHER RELEVANT FIXED SYSTEMS AND EQUIPMENT <i>(Clause 15i)</i>				
24.01	Type of other fixed system(s) installed:				Provide a system of roof ventilators, activated by automatic fire detectors.
24.02	Are there appropriately sited facilities for electrical isolation of any photovoltaic (PV) cells, with appropriate signage, to assist the fire and rescue service?				Install isolation device on solar panels and inform fire authority so it can be logged on IRS.
	Observations:				

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
25.00	PROCEDURES AND ARRANGEMENTS (Clause 16)				
25.01	Safety assistance:	✓	✓	✓	The competent person(s) appointed under Article 18 of the Fire Safety Order to assist the responsible person in undertaking the preventive and protection measures (i.e. relevant general fire precautions) is # ADD NAME HERE#.
25.02	Fire safety at the premises is managed by:				The fire safety at the premises is managed by #ADD MANAGEMENT PERSON OR CONTRACTOR HERE#
25.03	Is there a suitable record of the fire safety arrangements?				Review fire emergency plan to detail required fire safety arrangements.
25.04	Evacuation strategy:				The evacuation strategy for this sleeping risk premises is: Stay put / Simultaneous evacuation / Other (please specify)
25.05	Are procedures in the event of a fire appropriate and properly documented, where appropriate?				Add more required detail into the fire emergency plan (FEP).
25.06	Are routine in-house inspections of fire precautions undertaken (e.g. in the course of health and safety inspections?				Ensure that all required routine fire inspections are carried out.
	Observations:				
26.00	TRAINING AND DRILLS (Clause 16h)				
26.01	Are all staff given adequate fire safety instruction and training on induction?				Introduce an appropriate induction training presentation for the workplace.
26.02	When the employees of another employer work in the premises, is appropriate information on the fire risks and fire safety measures provided?				Provide other employees staff with information, instruction or training on the fire safety measures on the premises.
	Observations:				
27.00	TESTING AND MAINTENANCE (Clause 16j)				
27.01	Is there adequate maintenance of the premises?				Ensure that checks, inspections and maintenance are carried out at appropriate intervals.
27.02	Is weekly testing and periodic servicing of fire detection and alarm system undertaken?				Ensure that weekly fire alarm test and periodic servicing are carried out and recorded by competent persons.
27.03	Is monthly and annual testing routines for emergency lighting?				Ensure that monthly, six monthly and annual emergency lighting carried out and recorded by competent persons.
27.04	Is annual maintenance of fire extinguishing appliances undertaken?				Ensure that monthly checks, and annual maintenance of portable fire fighting appliances are carried out and recorded by competent persons.
27.05	Are six-monthly inspection and annual testing of rising mains undertaken?				Arrange six-monthly inspection and annual pressure testing of dry riser.

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
27.06	Are weekly and monthly testing, six monthly inspection and annual testing of fire-fighting lift(s) provided for the use by firefighters or evacuation of disabled people (evacuation lifts)?				Arrange weekly and monthly testing, six monthly inspection and annual testing of fire-fighting or evacuation lifts.
27.07	Other relevant inspections or tests?				Ensure that periodic inspections of sprinkler or ventilation systems are carried out and recorded by competent persons.
	Observations:				
28.00	RECORDS (Clause 16k)				
28.01	Are there appropriate records of:				
28.01 a)	Fire alarm tests (where relevant)?				Provide and maintain a register of records for fire alarm tests.
28.01 b)	Emergency escape lighting tests?				Provide and maintain a register of records for emergency lighting tests.
28.01 c)	Maintenance and testing of other fire protection equipment?				Provide and maintain a register of records for fixed fire system tests.
29.09	Is the fire emergency plan available to the enforcing authority?				Ensure that fire emergency plan is readily available for enforcing authority inspection.
29.10	Are Personal Emergency Evacuation Plans (PEEPS) required and in place?				Ensure that Personal Emergency Evacuation Plans are compiled in accordance DCLG guidance and is readily available for enforcing authority inspection.
	Observations:				
29.00	PREMISES INFORMATION BOX (Clause 15c)				
29.01	Is there a suitably located premises information box for the fire and rescue service?				Provide premises information box with details to assist the fire and rescue service.
29.02	Are there arrangements to keep the premises information box up to date?				Regularly check and update the premises information box.
30.00	ENGAGEMENT WITH RESIDENTS (Clause 16l)				
30.01	Has information on fire procedures been disseminated to residents?				Provide a clear fire action document for all residents.
30.02	Is fire safety information disseminated to residents?				Provide a clear fire safety information for all residents.

FIRE RISK ASSESSMENT RISK REGISTER

Risk Value Matrix

Likelihood	Value	Severity of Outcome(s)
Negligible	1	Negligible
Low	2	Minor injury to occupants, first aid required
Moderate	3	Moderate Injury to occupants, medical attention required.
High	4	Occupants required hospitalisation.
Extreme	5	Major loss of life.

	Likelihood				
Severity	1	2	3	4	5
	2	4	6	8	10
	3	6	9	12	15
	4	8	12	16	20
	5	10	15	20	25

Likelihood

Severity

Risk Rating Score:

Risk Rating	Action PAS 79-1:2020
Trivial	Record findings and review in 12 months
Tolerable	No major additional controls required. However, There might be a need for improvements that involve minor or limited costs.
Moderate	It is essential that efforts are made to reduce the risk. Risk reduction measures should be implemented within a defined time period. Where moderate risk is associated with consequences that constitute extreme harm, further assessment might be required to establish more precisely the likelihood of harm as a basis for determining the priority for improved control measures.
Substantial	Considerable resources might have to be allocated to reduce the risk. If the building is unoccupied, it should not be occupied until the risk has been reduced. If the building is occupied, urgent action should be taken.
Intolerable	Building (or relevant area) should not be occupied until the risk is reduced.

Fire Risk Assessment Review

Assessments should be kept under constant review, and in any case reviewed whenever circumstance change which affect the validity of the current assessment. Whilst there is no maximum period between assessments, it is recommended that the review period should not exceed 12 months.

QUESTION	SIGNIFICANT HAZARDS	RESPONSIBLE PERSON	TARGET DATE	DATE COMPLETED & INITIAL
7.00	ELECTRONIC SOURCES OF IGNITION (Clause 13 and Annex B)			
7.01	Maintain safe separation distance of ½ metre between appliance and combustible materials. Enclose electrical intake in 30 or 60 minute fire resisting enclosure. Prohibit any combustible or flammable storage in electrical intake room. Ensure that sources of heat do not arise from faulty or overloaded electrical equipment. Ensure that all electrical fuses and circuit breakers etc. of the correct rating and suitable for the purpose. Switch equipment off at the end of the working day.			
7.02 a)	Introduce a programme of inspection and tests by a competent electrician to the current EICR certificate.			
7.02 b)	Have workplace portable electrical appliances tested by a competent person.			
8.00	SMOKING (Clause 13 and Annex B)			
8.01	Introduce a safe smoking policy in designated smoking areas and enforce prohibiting smoking elsewhere.			
8.02 a)	Introduce a safe smoking policy in designated smoking areas and enforce prohibiting smoking elsewhere.			
8.02 b)	Introduce a safe smoking policy in designated smoking areas and enforce prohibiting smoking elsewhere.			
8.02 c)	Introduce a safe smoking policy in designated smoking areas and enforce prohibiting smoking elsewhere.			
8.02 d)	Add "No smoking" signage at main entrance and other areas if required.			
9.00	ARSON (Clause 13 and Annex B)			
9.01	Have a security specialist advise on additional precautions to avoid the risk of arson.			
9.02	Remove or relocate any fire load in close proximity to the premises and control access for ignition by outsiders.			
10.00	PORTABLE HEATERS, HEATING AND VENTILATION SYSTEMS (Clause 13 and Annex B)			
10.01	Ban the use of portable heaters in the workplace and adjust fixed heating accordingly.			
10.02	Arrange for heating and ventilation system to be maintained by a competent contractor.			

QUESTION	SIGNIFICANT HAZARDS	RESPONSIBLE PERSON	TARGET DATE	DATE COMPLETED & INITIAL
11.00	COOKING (Clause 13 and Annex B)			
11.01	Maintain safe separation distance between appliances and flammable/combustible materials. Introduce safe working practices.			
12.00	LIGHTNING (Clause 13 and Annex B)			
12.01	Provide suitable lightning protection system to building in accordance with BS EN 62305-1:2011.			
13.00	HOUSEKEEPING (Clause 13 and Annex B)			
13.01	Ensure a programme is introduced to improve housekeeping.			
13.02 a)	Maintain safe separation distance of ½ metre between appliance and combustible storage.			
13.02 b)	Remove and manage unnecessary waste or storage.			
13.02 c)	Manage plant area access and inform staff and/or residents that they must be kept clear at all times due to the likelihood of ignition.			
14.00	HAZARDS INTRODUCED BY OUTSIDE CONTRACTORS AND BUILDING WORKS (Clause 13 and Annex B)			
14.01	Impose appropriate fire safety conditions on outside contractors.			
15.00	DANGEROUS SUBSTANCES (Clause 13)			
15.01	Reduce the quantity of dangerous substances to a minimum. Manage out collation of any dangerous substances.			
16.00	OTHER SIGNIFICANT FIRE HAZARDS THAT WARRANT CONSIDERATION			
16.01	List and detail any other significant hazards here:			
17.00	MEANS OF ESCAPE (Clause 15c) and Annex C)			
17.01	Improve the means of escape in as follows:			
17.02 a1)	Provide a pass door in the following locations: #add locations#. Provide external fire escape in the following location # add location#. Provide an additional exit to the escape corridor from the inner room #add location#.			

QUESTION	SIGNIFICANT HAZARDS	RESPONSIBLE PERSON	TARGET DATE	DATE COMPLETED & INITIAL
17.02 a2)	Provide external fire escape in the following location # add location#. Provide an additional exit to the escape corridor from the inner room #add location#.			
17.02 b)	Provide additional escape exits in the following locations #add location#.			
17.02 c)	Re-hang and recess the door to #add location# to open in the direction of escape.			
17.02 d)	Reduce the securing devices on final exit doors to a single device provided with a suitable sign on how to operate.			
17.02 e)	Repair or replace damaged partitions to the required fire resisting rating including 1.8m (England & Wales) or 2.0m (Scotland) rule to external staircases.			
17.02 f)	The following staircase and common area fire doors require attention: Fire door maintenance or installations should be actioned by a 3rd party accredited and competent contractor and must comply to the manufacturer recommendations or BS 8214:2016.			
17.02 g)	Install BS EN 1154 self closing devices to the following common area fire doors: Installations and maintenance should be actioned by a 3rd party accredited and competent contractor and must comply to the manufacturer recommendations or BS 8214:2016.			
17.02 h)	The following common area plant room fire doors require attention: Fire door maintenance or installations should be actioned by a 3rd party accredited and competent contractor and must comply to the manufacturer recommendations or BS 8214:2016.			
17.02 i)	The following flat entrance fire doors require attention: Fire door maintenance or installations should be actioned by a 3rd party accredited and competent contractor and must comply to the manufacturer recommendations or BS 8214:2016.			
17.02 j)	Install BS EN 1154 self closing devices to the following flat entrance fire doors: Installations and maintenance should be actioned by a 3rd party accredited and competent contractor and must comply to the manufacturer recommendations or BS 8214:2016.			
17.02 k)	Consider advice from a competent smoke control engineer.			
17.02 l)	Clear internal or external storage.			

QUESTION	SIGNIFICANT HAZARDS	RESPONSIBLE PERSON	TARGET DATE	DATE COMPLETED & INITIAL
17.02 m)	Remove one of the two securing devices from the final exit door from the #add location#. Install suitable interlocks on doors normally kept close for security reasons in the following locations: #add locations# . Provide a panic bolt/latch and appropriate sign on the final exit door from #add location#.			
17.02 n)	Improve escape options for disabled people. Move residence with mobility issues to the ground floor. Provide PEEPs or GEEPs where necessary.			
18.00	MEASURES TO LIMIT FIRE SPREAD AND DEVELOPMENT (Clause 15g)			
18.01 a)	Action a compartmentation survey by a competent contractor.			
18.01 b)	Remove the combustible construction and replace it with fire-resisting or non-combustible alternatives.			
18.01 c)	Have a roof compartmentation survey actioned by a competent contractor.			
18.01 d)	Have service risers and/or ducts inspected by a competent contractor.			
18.02	Have an invasive survey actioned by a fire damper competent specialist.			
19.00	EMERGENCY ESCAPE LIGHTING (Clause 15e)			
19.01	Provide emergency lighting to illuminate internal and external escape routes and points of emphasis.			
20.00	FIRE SAFETY SIGNS AND NOTICES (Clause 15d)			
20.01	Provide green moving person signs with appropriate directional arrows to indicate the secondary escape routes in the following locations: #add locations#.			
21.00	MEANS OF GIVING WARNING IN CASE OF FIRE (Clause 15b)			
21.01	See Sleeping Accommodation Home Office Fire guide P57 for recommended minimum fire alarm standards. Install an electrical fire alarm system conforming to BS 5839. Provide additional fire alarm call points linked into the existing system in the following locations: #add location#			
21.02	Actions required:			
21.03	Provide a fire alarm zone plan of the system adjacent to the main fire control panel.			

QUESTION	SIGNIFICANT HAZARDS	RESPONSIBLE PERSON	TARGET DATE	DATE COMPLETED & INITIAL
21.04	Consider how alarms will be reset when required, especially in a non staffed premises.			
22.00	MANUAL FIRE EXTINGUISHING APPLIANCES (Clause 15f)			
22.01	Are extinguishers required in common areas? Replace the non standard fire extinguishers with BS/LPC approved extinguishers in the following locations.			
22.02	Remove obstructions in the following places:			
23.00	RELEVANT AUTOMATIC FIRE EXTINGUISHING SYSTEMS (Clause 15h)			
23.01	0			
23.01 a)	Install sprinkler system if required and reasonably practicable due to life risk.			
23.01 b)	Install misting system if required and reasonably practicable due to life risk.			
24.00	OTHER RELEVANT FIXED SYSTEMS AND EQUIPMENT (Clause 15i)			
24.01	Provide a system of roof ventilators, activated by automatic fire detectors.			
24.02	Install isolation device on solar panels and inform fire authority so it can be logged on IRS.			
25.00	PROCEDURES AND ARRANGEMENTS (Clause 16)			
25.03	Review fire emergency plan to detail required fire safety arrangements.			
25.04	The evacuation strategy for this sleeping risk premises is: Stay put / Simultaneous evacuation / Other (please specify)			
25.05	Add more required detail into the fire emergency plan (FEP).			
25.06	Ensure that all required routine fire inspections are carried out.			
26.00	TRAINING AND DRILLS (Clause 16h)			
26.01	Introduce an appropriate induction training presentation for the workplace.			
26.02	Provide other employees staff with information, instruction or training on the fire safety measures on the premises.			
27.00	TESTING AND MAINTENANCE (Clause 16j)			
27.01	Ensure that checks, inspections and maintenance are carried out at appropriate intervals.			
27.02	Ensure that weekly fire alarm test and periodic servicing are carried out and recorded by competent persons.			

QUESTION	SIGNIFICANT HAZARDS	RESPONSIBLE PERSON	TARGET DATE	DATE COMPLETED & INITIAL
27.03	Ensure that monthly, six monthly and annual emergency lighting carried out and recorded by competent persons.			
27.04	Ensure that monthly checks, and annual maintenance of portable fire fighting appliances are carried out and recorded by competent persons.			
27.05	Arrange six-monthly inspection and annual pressure testing of dry riser.			
27.06	Arrange weekly and monthly testing, six monthly inspection and annual testing of fire-fighting or evacuation lifts.			
27.07	Ensure that periodic inspections of sprinkler or ventilation systems are carried out and recorded by competent persons.			
28.00	RECORDS (Clause 16k)			
28.01 a)	Provide and maintain a register of records for fire alarm tests.			
28.01 b)	Provide and maintain a register of records for emergency lighting tests.			
28.01 c)	Provide and maintain a register of records for fixed fire system tests.			
29.00	PREMISES INFORMATION BOX (Clause 15c)			
29.01	Provide premises information box with details to assist the fire and rescue service.			
29.02	Regularly check and update the premises information box.			
30.00	ENGAGEMENT WITH RESIDENTS (Clause 16l)			
30.01	Provide a clear fire action document for all residents.			
30.02	Provide a clear fire safety information for all residents.			

PHOTOGRAPHS

To add page breaks after each page:

<Page Layout>

<Breaks>

<Insert Page Break>

To remove page breaks:

<Page Layout>

<Breaks>

<Reset all page breaks>