

Action Plan Section

Action Plan

Index ID	Significant Findings / Action Plan	Responsible Person	Target Date
11.00	COOKING (Clause 13 and Annex B)		
11.02	Grease filters and clean ductwork should have maintenance on a regular basis to reduce the risk of fire.	Test Persom	2025-02-06
12.00	LIGHTNING (Clause 13 and Annex B)		
12.01	Provide suitable lightning protection system to building in accordance with BS EN 62305-1:2011.	Test Persom	2025-02-19