

Action Plan Section

Action Plan

Index ID	Significant Findings / Action Plan	Responsible Person	Target Date
7.00	ELECTRONIC SOURCES OF IGNITION (Clause 13 and Annex B)		
7.01	Maintain safe separation distance of 1½ metre between appliance and combustible materials. Enclose electrical intake in 30 or 60 minute fire resisting enclosure. Prohibit any combustible or flammable storage in electrical intake room. Ensure that sources of heat do not arise from faulty or overloaded electrical equipment. Ensure that all electrical fuses and circuit breakers etc. of the correct rating and suitable for the purpose. Switch equipment off at the end of the working day.	Test Responsible	2025-02-11
13.00	HOUSEKEEPING (Clause 13 and Annex B)		
13.01	Ensure a programme is introduced to improve housekeeping.	TEst	2025-02-18
17.00	MEANS OF ESCAPE (Clause 15c and Annex C)		
17.02a1	Provide a pass door in the following locations: [add locations]. Provide external fire escape in the following location: [add location]. Provide an additional exit to the escape corridor from the inner room: [add location].	Test Person	2025-02-26
18.00	MEASURES TO LIMIT FIRE SPREAD AND DEVELOPMENT (Clause 15g)		
18.01	N/A	Test	2025-02-18
25.00	PROCEDURES AND ARRANGEMENTS (Clause 16)		
25.06	Ensure that all required routine fire inspections are carried out.	Test Person	2025-02-11