

REGULATORY REFORM (FIRE SAFETY) ORDER 2005 FIRE RISK ASSESSMENT

Company Name

Address1

Address2

Address3

Address4

Responsible person (e.g. employer) or person having control of premises:	
Address of premises:	
Person(s) consulted:	
Assessor:	#Add your name and information here#
Assessors statement:	The purpose of this PAS 79-1:2020 (Annex A) report is to provide a non-invasive assessment of the risk to life from fire in these premises, and, where appropriate, to make recommendations to ensure compliance with fire safety legislation. This report does not address the risk to property or business continuity from fire. I certify that to the best of my knowledge, the information contained in this fire risk assessment is correct, based on information provided at the time the assessment was undertaken.
Report validated by:	<i>Note: This is required for Tier 3 fire risk assessors to check other colleagues reports under BAFE SP205 or FRACCS etc.. Otherwise add N/A HERE.</i>
Date of fire risk assessment:	
Date of previous fire risk assessment:	
Suggested date for review:	<i>Note: Usually 12 months as recommended in the Health and Safety at Work Act 1974.</i>
Fire Risk Assessment Review:	This fire risk assessment should be reviewed by a competent person by the date indicated above or at such earlier time as there is reason to suspect that it is no longer valid, or there has been significant change in the matters to which it relates, or if a fire occurs.
Report compliance:	This report is intended to assist you in compliance with Article 9 of the Regulatory Reform (Fire Safety) Order 2005 which requires that a fire risk assessment be carried out.

1.00	THE PREMISES (Clause 12)	
1.01	Number of floors at ground level and above:	
	Number of floors entirely below ground level:	
	Floors on which car parking is provided:	
1.02	Approximate floor area per floor:	m ² per floor.
	Approximate floor area gross:	m ² gross.
	Approximate floor area on ground floor:	m ² on ground floor.
1.03	Details of construction and layout: <i>Prompt: Give a detailed & clear overview of the building so it can be visualised including building age, how many internal/external stairways, lifts and final exits.</i>	
1.04	Occupancy: (Including hours of business) <i>e.g. Office, shop, restaurant, warehouse, factory, hotel, hospital, residential care home etc...</i>	
2.00	THE OCCUPANTS (Clause 12)	
2.01	Approximate maximum number of employees at any one time:	
2.02	Approximate maximum number of other occupants at any one time:	
2.03	Approximate total number of people present in the building at any one time:	
3.00	OCCUPANTS ESPECIALLY AT RISK FROM FIRE (Clause 12)	
3.01	Sleeping occupants	
3.02	Disabled employees:	
3.03	Other disabled occupants:	
3.04	Occupants in remote areas and lone workers:	
3.05	Young persons:	
3.06	Others:	
4.00	FIRE LOSS EXPERIENCE	

4.01	Fires in past 10 years:	
4.02	Cost of past fire losses:	
5.00	OTHER RELEVANT INFORMATION	
5.01	Detail if required: <i>Prompt: Add type of fire alarm system, sprinklers, misting, gaseous flooding, AOVs etc...</i>	
6.00	RELEVANT FIRE SAFETY LEGISLATION	
6.01	The following fire safety legislation applies to these premises:	<i>Regulatory (Fire Safety) Order 2005 and Building Safety Act 2022. Or Fire (Scotland) Act 2005 and The Fire Safety (Scotland) Regulations 2006 (amend as required).</i>
6.02	The above legislation is enforced by:	<i>_____ Fire & Rescue Service, London Fire Brigade or HSE (for construction or refurbishment enforcement) - (amend as required).</i>
6.03	Other legislation that makes significant requirements for fire precautions in these premises:	<i>Other fire Acts outside of UK Legislation e.g.) The Safety of Sports Grounds Act 1975 and The Safety of Places of Sport Act 1987, United Kingdom Atomic Energy Authority etc... Otherwise N/A.</i>
6.04	The other legislation referred to above is enforced by:	<i>Local Authority (for Sports Grounds only if relevant)</i>
6.05	Is there an alterations notice in force?	
6.06	Relevant information and deficiencies observed:	
6.07	Other information: <i>Prompt: This text area can be used to add reference fire guide and method of evacuation.</i>	<i>eg) Home Office offices & shops fire guide. eg) Single-Stage Evacuation or Horizontal Evacuation etc...</i>

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
7.00	ELECTRONIC SOURCES OF IGNITION (Clause 13 and Annex B)				
7.01	Are reasonable measures taken to prevent fires of electrical origin?	✓	✓	✓	If there is not reasonable measures, tick NO and add recommendations of what action should be required here. Example 1: Combustible storage should be a safe separation distance of ½ metre or more from an electrical appliance. Example 2: Electrical intake should be enclosed into a 30 minute fire resisting enclosure. Example 3: Combustible or flammable storage should be prohibited from the electrical intake room and managed regularly to be kept sterile at all times as recommended in the Home Office good practice fire guides. Example 4: Electrical equipment should be switched off when not in use and at the end of the working day. If YES or N/A delete control measure.
7.02	More specifically:				
7.02 a)	Are fixed installations periodically inspected and tested?				Introduce a programme of inspection and tests by a competent electrician to the current EICR certificate.
7.02 b)	Is portable appliance testing carried out?				Consider having portable electrical appliances tested yearly by a competent person to reduce the risk of electronic sources of ignition.
7.02 c)	Is there suitable control over the use of personal electrical appliances?				Consider having personal portable electrical appliances tested by a competent person.
7.02 d)	Is there suitable limitation of trailing leads and adapters?				Provide one electrical socket for each electrical appliance and appoint a competent contractor to carry out any required installation work.
	Observations: (PAS 79: 2020 states all observations should be small font size and italic and not be included in the action plan/significant findings report)				Note: Add supporting text here to justify why you've ticked the questions in the section above or to back up why you've ticked Yes or N/A. When you've ticked No, there should be a action to recommend what is required to reduce the risk in a pragmatic/reasonably practical manner.
8.00	SMOKING (Clause 13 and Annex B)				
8.01	Are reasonable measures taken to prevent fires as a result of smoking?				Introduce a safe smoking policy in designated smoking areas and enforce prohibiting smoking elsewhere.
8.02	More specifically:				
8.02 a)	Is smoking prohibited in the building?				Enforce the prohibition of smoking in the premises.
8.02 b)	Is smoking prohibited in appropriate areas?				Introduce a safe smoking policy in designated smoking areas and enforce prohibiting smoking elsewhere.
8.02 c)	Are there suitable arrangements for those who wish to smoke?				Introduce a safe smoking policy in designated smoking areas and enforce prohibiting smoking elsewhere.

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
8.02 d)	Did the smoking policy appear to be observed at the time of inspection?				Evidence of covert smoking was seen at the back of the premises (used cigarette filters) close to fire exit 8. Ensure all staff are aware this is unacceptable and smoking or vaping should only be performed in designated smoking areas.
	Observations: <i>Prompt: Add info to clarify why you have ticked questions under each section especially if there are no actions under that section.</i>				<i>e.g.) There were no signs of covert smoking during the FRA site visit and the external smoking area is checked/managed daily by nominated staff.</i>
9.00	ARSON (Clause 13 and Annex B)				
9.01	Does basic security against arson by outsiders appear reasonable?				Have a security specialist advise on additional precautions to avoid the risk of arson.
9.02	Is there an absence of unnecessary fire load in close proximity to the premises or available for ignition by outsiders?				Remove or relocate any fire load in close proximity to the premises and control access for ignition by outsiders?
	Observations:				<i>e.g.) If there are no concerns/actions for potential Arson, add a clarification statement here to justify low risk etc...</i>
10.00	PORTABLE HEATERS, HEATING AND VENTILATION SYSTEMS (Clause 13 and Annex B)				
10.01	Is there satisfactory control over the use of portable heaters?				Ban the use of portable heaters in the workplace and adjust fixed heating accordingly.
10.02	Are fixed heating and ventilation installations subject to regular maintenance?				Arrange for heating and ventilation system to be maintained by a competent contractor.
	Observations:				<i>e.g.) There are no portable heaters used or stored on-site. HVAC system was last checked by a competent contractor on 03/09/2022.</i>
11.00	COOKING (Clause 13 and Annex B)				
11.01	Are reasonable measures taken to prevent fires as a result of cooking?				Maintain safe separation distance between appliances and flammable/combustible materials.
11.02	More specifically, are filters cleaned or changed and ductwork cleaned regularly?				Grease filters and clean ductwork should have maintenance on a regular basis to reduce the risk of fire.
	Observations:				
12.00	LIGHTNING (Clause 13 and Annex B)				
12.01	Does the building have a lightning protection system?				Provide suitable lightning protection system to building in accordance with BS EN 62305-1:2011.

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
	Observations:				
13.00	HOUSEKEEPING (Clause 13 and Annex B)				
13.01	Is the overall standard of housekeeping adequate?				Ensure a programme is introduced to improve housekeeping.
13.02	More specifically:				
13.02 a)	Do combustible materials appear to be separated from ignition sources?				Maintain safe separation distance of ½ metre between appliance and combustible storage.
13.02 b)	Is unnecessary accumulation or inappropriate storage of combustible materials or waste avoided?				External bin waste or internal storage should be managed to a higher standard and checked on regular intervals.
	Observations:				
14.00	HAZARDS INTRODUCED BY OUTSIDE CONTRACTORS AND BUILDING WORKS (Clause 13 and Annex B)				
14.01	Is there satisfactory control over works carried out in the building?				Impose appropriate fire safety conditions on outside contractors.
14.02	More specifically:				
14.02 a)	Where appropriate, are fire safety conditions imposed on outside contractors?				Introduce a safe system of work for contractors who carry out work within the workplace.
14.02 b)	Where appropriate, is a permit to work system used (e.g. for "hot work")?				Introduce a hot work permit system.
14.02 c)	Are suitable precautions taken by in-house maintenance personnel who carry out works?				Introduce a permit to work system for in-house maintenance workers who carry out 'hot work' involving processes such as welding or flame cutting.
	Observations:				
15.00	DANGEROUS SUBSTANCES (Clause 13)				

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
15.01	Are the general fire precautions adequate to address the hazards associated with dangerous substances used or stored within the premises?				Examples: Reduce the quantity of dangerous substances to a minimum. Ensure that any release of a dangerous substance which may give rise to risk is suitably collected, safely contained, removed to a safe place, or otherwise rendered safe, as appropriate. Avoid ignition sources including electrostatic discharges. Arrange a DSEAR risk assessment by a competent contractor and reviews should be made regularly, especially when there is a significant change in use of substances or quantities.
	Observations:				
16.00	OTHER SIGNIFICANT FIRE HAZARDS THAT WARRANT CONSIDERATION				
16.01	Hazards:				List and detail any other significant hazards here if applicable?

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
17.00	MEANS OF ESCAPE (Clause 15c) and Annex C)				
17.01	Is the design and maintenance of the means of escape considered adequate?	✓	✓	✓	Improve the means of escape in as follows:
17.02	More Specifically:				
17.02 a)	Do staircase and exit capacities appear to be adequate for the number of occupants?				Increase the width of the escape corridors to 1.2 metres.
17.02 b)	Are there reasonable distances of travel:				
17.02 b1)	Where there is escape in a single direction?				Provide a pass door in the following locations: #add locations#. Provide external fire escape in the following location # add location#. Provide an additional exit to the escape corridor from the inner room #add location#.
17.02 b2)	Where there are alternative means of escape?				Provide external fire escape in the following location # add location#. Provide an additional exit to the escape corridor from the inner room #add location#.
17.02 c)	Is there adequate provision of exits?				Provide additional escape exits in the following locations #add location#.
17.02 d)	Do fire exits open in the direction of escape, where necessary?				Re-hang and recess the door to #add location# to open in the direction of escape.
17.02 e)	Are there satisfactory arrangements for escape where revolving or sliding doors are used as exits?				Provide pass final exit doors adjacent to revolving or sliding doors in the following locations #add locations#.
17.02 f)	Are the arrangements provided for securing exits satisfactory?				Reduce the securing devices on final exit doors to a single device provided with a suitable sign on how to operate.
17.02 g)	Is a suitable standard of protection designed for escape routes?				Repair or replace damaged partitions to the required fire resisting rating including 1.8m (England & Wales) or 2.0m (Scotland) rule to external staircases.
17.02 h)	Are there reasonable arrangements for means of escape for disabled people?				Train fire marshals in how to use evac chairs provided/place in safe refuge such as fire rated staircase enclosure/relocate such workers or visitors to ground floor accommodation only. Provide evacuation lifts or fire lifts used to evacuate disabled people from upper floors. Provide a suitable refuge within the staircase enclosure in the following locations: Ensure communication equipment in refuge is tested regularly as required.
17.03	Are the escape routes available for use and suitably maintained?				Make sure escape routes are clear and ready for immediate use at any time.
17.04	More Specifically:				

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
17.04 a)	Are fire-resisting doors maintained in sound condition and self closing, where necessary?				The following fire doors have gaps between door and frame. Provide self closing devices to the following doors. The following doors have damage. Installations and maintenance should be actioned by a 3rd party accredited and competent contractor and must comply to the manufacturer recommendations or BS 8214:2016.
17.04 b)	Is the fire-resisting construction protecting escape routes in sound condition?				Arrange a competent contractor to survey and complete required works.
17.04 c)	Are all escape routes clear of obstructions?				Clear internal or external storage.
17.04 d)	Are all fire exits easily and immediately openable?				Remove one of the two securing devices from the final exit door from the #add location#. Install suitable interlocks on doors normally kept close for security reasons in the following locations: #add locations# . Provide a panic bolt/latch and appropriate sign on the final exit door from #add location#.
	Observations:				
18.00	MEASURES TO LIMIT FIRE SPREAD AND DEVELOPMENT (Clause 15g)				
18.01	Is it considered that there is:				
18.01 a)	Compartmentation of a reasonable standard?				Repair or replace damaged compartment walls to the required fire resisting rating. Repair or replace damaged compartment floors or ceilings to the required fire resisting rating.
18.01 b)	Reasonable limitation of linings that may promote fire spread?				Replace furniture that is damaged/perished as they are a fire hazard. Reduce risk by removing, covering or treating large areas of flammable wall and ceiling linings to reduce the rate of flame spread across the surface.
18.02	As far as can be reasonably be ascertained, are fire dampers provided necessary to protect critical means of escape against passage of fire, smoke and products of combustion in the early stages of a fire?				Have a survey actioned by a fire damper competent contractor.
	Observations:				
19.00	EMERGENCY ESCAPE LIGHTING (Clause 15e)				
19.01	Has a reasonable standard of emergency escape lighting system been provided?				Provide emergency lighting to illuminate internal and external escape routes and points of emphasis.

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
	Observations:				
20.00	FIRE SAFETY SIGNS AND NOTICES (Clause 15d)				
20.01	Is there a reasonable standard of fire safety signs and notices?				Provide green moving person signs with appropriate directional arrows to indicate the secondary escape routes in the following locations: #add locations#.
	Observations:				
21.00	MEANS OF GIVING WARNING IN CASE OF FIRE (Clause 15b)				
21.01	Is a reasonable fire detection and fire alarm system provided?				Install an electrical fire alarm system conforming to BS 5839. Install a fire control panel that can be seen from the outside through an entrance to the building. Install a fire control repeater panel linked to the existing system on an external wall. Provide additional fire alarm call points linked into the existing system in the following locations: #add location#
21.02	Is there remote transmission of alarm signals?				Install an auto-dialler device to inform an alarm receiving centre of a fire alarm activation via a secure telephone line.
21.03	Is a zone plan of the fire alarm system displayed?				Consider providing a zone plan of the system adjacent to the fire control panel.
21.04	Has the premises had false alarms experience?				Reduce false alarms by replacing smoke detector with a heat detector in the kitchen.
	Observations:				
22.00	MANUAL FIRE EXTINGUISHING APPLIANCES (Clause 15f)				
22.01	Is there reasonable provision of manual fire extinguishing appliances?				Replace the non standard fire extinguishers with BS/LPC approved extinguishers in the following locations.
22.02	What type(s) of appliances are provided:				
22.02 a)	Portable fire extinguishers:				Add portable fire extinguishers.
22.02 b)	Hose reels:				Remove hose reels and replace with modern portable extinguishers.
22.02 c)	Fire blankets:				Add fire blankets in the kitchen.
22.03	Are all fire extinguishing appliances readily accessible?				Remove obstructions in the following places:
	Observations:				

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
23.00	RELEVANT AUTOMATIC FIRE EXTINGUISHING SYSTEMS <i>(Clause 15h)</i>				
23.01	Type of fixed system(s):				
23.01 a)	Sprinkler system?				Install sprinkler system if required and reasonably practicable due to life risk.
23.01 b)	Misting system?				Install misting system if required and reasonably practicable due to life risk.
23.01 c)	Kitchen suppression system?				Install kitchen suppression system if required and reasonably practicable due to life risk.
23.01 d)	Inert gas flooding system?				Install gas flooding system if required and reasonably practicable due to life risk.
	Observations: <i>(List fixed systems)</i>				<i>Sprinkler system type: Misting system type: Kitchen suppression system type: Gaseous flooding system type:</i>
24.00	OTHER RELEVANT FIXED SYSTEMS AND EQUIPMENT <i>(Clause 15i)</i>				
24.01	Type of other fixed system(s) installed:				Provide a system of roof ventilators, activated by automatic fire detectors and sub-divide roof into appropriate smoke reservoirs.
24.02	Is there suitable provisions of firefighters' switch(es) for high voltage isolation of luminous tube signs, etc.?				Install isolation device and inform fire authority that neon signs are installed so it can be logged on IRS.
24.03	Are there appropriately sited facilities for electrical isolation of any photovoltaic (PV) cells, with appropriate signage, to assist the fire and rescue service?				Install isolation device on solar panels and inform fire authority so it can be logged on IRS.
	Observations:				

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
25.00	PROCEDURES AND ARRANGEMENTS (Clause 16)				
25.01	Safety assistance:	✓	✓	✓	The competent person(s) appointed under Article 18 of the Fire Safety Order to assist the responsible person in undertaking the preventive and protection measures (i.e. relevant general fire precautions) is # ADD Fire Safety Managers NAME HERE#.
25.02	Fire safety at the premises is managed by:				The fire safety at the premises is managed by #ADD Fire Safety Manager or Contractor's name HERE#
25.03	Is there a suitable record of the fire safety arrangements?				Review fire emergency plan to detail required fire safety arrangements.
25.04	Are procedures in the event of fire appropriate and properly documented, where appropriate?				Formulate and document fire procedures for the premises.
	More specifically:				
25.04 a)	Are there adequate procedures for investigating fire alarm signals?				Make arrangements for investigating fire alarm signals.
25.04 b)	Are there suitable arrangements for summoning the fire and rescue service?				Ensure that the plan provide clear instructions on procedures for liaising with the fire brigade on arrival.
25.04 c)	Are there suitable arrangements to meet the fire and rescue service on arrival and provide them with relevant information, including that relating to hazards to firefighters?				Ensure that the plan gives clear instructions of any special risks on the premises.
25.04 d)	Are there suitable arrangements for ensuring that the premises have been evacuated?				Ensure that there are suitable arrangements for ensuring that the premises have been evacuated.
25.04 e)	Is there suitable fire assembly point(s)?				Ensure that there a suitable fire assembly point(s).
25.04 f)	Are there adequate procedures for evacuation of any disabled people who are likely to be present?				Ensure that there adequate PEEPs or GEEPs for the evacuation of any disabled people who are likely to be present.
25.05	Are there persons nominated and trained to use fire extinguishing appliances?				Nominate persons to be trained to use fire extinguishing appliances.
25.06	If the premises are in multiple occupation, are there adequate arrangements for cooperation between duty holders to ensure coordination of their fire safety arrangements?				Ensure fire emergency plan covers multiple occupied premises.
25.07	Are there persons nominated to assist with evacuation of disabled people?				Nominate persons to assist with evacuation of disabled people.

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
25.08	Is there appropriate liaison with the fire and rescue service (i.e. by fire and rescue service crews visiting for familiarization visits?)				Arrange for the local fire and rescue service to carry out pre-fire inspections of the premises.
25.09	Are routine in-house inspections of fire precautions undertaken (e.g. in the course of health and safety inspections?)				Ensure that all required routine fire inspections are carried out.
	Observations:				
26.00	TRAINING AND DRILLS (Clause 16h)				
26.01	Are all staff given adequate fire safety instruction and training on induction?				Introduce an appropriate induction training presentation for the workplace.
	More specifically:				
26.01 a)	Are they trained on induction?				Arrange induction training for all new staff.
26.01 b)	Are they given periodic refresher training?				Arrange periodic training for all staff on fire awareness.
26.01 c)	Are they given additional training to cover any specific roles and responsibilities?				Arrange additional training for staff with specific roles.
26.01 d)	Is the content of the training provided considered adequate?				Add content to existing training as follows:
26.02	Are fire drills carried out at appropriate intervals?				Arrange fire drills for every six months for the building occupiers. Ensure out of hour workers also participate in additional fire drills every six months.
26.03	When the employees of another employer work in the premises, is appropriate information on the fire risks and fire safety measures provided?				Provide other employees staff with information, instruction or training on the fire safety measures on the premises.
	Observations:				<i>Prompt: Add HERE how many fire wardens are currently trained and make sure there is an action above if you feel there needs to be more trained. The Fire Emergency Plan should list the names of the current trained fire wardens.</i>
27.00	TESTING AND MAINTENANCE (Clause 16j)				
27.01	Is there adequate maintenance of the premises?				Ensure that checks, inspections and maintenance are carried out at appropriate intervals.
27.02	Is weekly testing and periodic servicing of fire detection and alarm system undertaken?				Senior fire marshal to ensure that weekly fire alarm test and periodic servicing are carried out and recorded by competent persons.
27.03	Is monthly and annual testing routines for emergency lighting?				Senior fire marshal to ensure that monthly and annual emergency lighting tests are carried out and recorded by competent persons.

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
27.04	Is annual maintenance of fire extinguishing appliances undertaken?				Ensure that monthly checks, and annual maintenance of portable fire fighting appliances are carried out and recorded by competent persons.
27.05	Is periodic inspection of external escape staircases and gangways undertaken?				Arrange the periodic inspection of external escape staircase and gangways.
27.06	Are six-monthly inspection and annual testing of rising mains undertaken?				Arrange six-monthly inspection and annual pressure testing of dry riser.
27.07	Are weekly and monthly testing, six monthly inspection and annual testing of fire-fighting lift(s) provided for the use by firefighters or evacuation of disabled people (evacuation lifts)?				Arrange weekly and monthly testing, six monthly inspection and annual testing of fire-fighting or evacuation lifts.
27.08	Are weekly testing and periodic inspection of sprinkler installations undertaken?				Arrange periodic testing for sprinkler system by a competent person.
27.09	Are routine checks of final exit doors and/or security fastenings undertaken?				Arrange routine checks of final exit doors and security fastenings.
27.10	Is an annual inspection of lightning protection system undertaken?				Arrange the annual inspection of lightning protection system.
27.11	Other relevant inspections or tests?				Ensure that periodic inspections of Inergen/FM200/Argonite total flooding/local application system are carried out and recorded by competent persons.
	Observations:				
28.00	RECORDS (Clause 16k)				
28.01	Are there appropriate records of:				
28.01 a)	Fire drills?				Provide and maintain a register of records for fire drills.
28.01 b)	Fire Training?				Provide and maintain a register of records for fire training.
28.01 c)	Fire alarm tests?				Provide and maintain a register of records for fire alarm tests.
28.01 d)	False alarms?				Provide and maintain a register of records for false alarms.
28.01 e)	Emergency escape lighting tests?				Provide and maintain a register of records for emergency lighting tests.
28.01 f)	Maintenance and testing of other fixed fire protection systems?				Provide and maintain a register of records for fixed fire system tests.
28.01 g)	Is the fire emergency plan for the premises adequate?				Review and add more relevant detail to the fire emergency plan.
29.09	Is the fire emergency plan available to the enforcing authority?				Ensure that fire emergency plan is readily available for enforcing authority inspection.

INDEX	DETAIL	YES	NO	N/A	CONTROL MEASURES
29.10	Are Personal Emergency Evacuation Plans (PEEPS) required and in place?				Ensure that Personal Emergency Evacuation Plans are compiled in accordance with Home Office guidance and is readily available for enforcing authority inspection.
	Observations:				

FIRE RISK ASSESSMENT RISK REGISTER

Risk Value Matrix

Likelihood	Value	Severity of Outcome(s)
Negligible	1	Negligible
Low	2	Minor injury to occupants, first aid required
Moderate	3	Moderate Injury to occupants, medical attention required.
High	4	Occupants required hospitalisation.
Extreme	5	Major loss of life.

	Likelihood				
Severity	1	2	3	4	5
1	1	2	3	4	5
2	2	4	6	8	10
3	3	6	9	12	15
4	4	8	12	16	20
5	5	10	15	20	25

Likelihood

Severity

Risk Rating Score:

Risk Rating	Action PAS 79-1:2020
Trivial	Record findings and review in 12 months
Tolerable	No major additional controls required. However, There might be a need for improvements that involve minor or limited costs.
Moderate	It is essential that efforts are made to reduce the risk. Risk reduction measures should be implemented within a defined time period. Where moderate risk is associated with consequences that constitute extreme harm, further assessment might be required to establish more precisely the likelihood of harm as a basis for determining the priority for improved control measures.
Substantial	Considerable resources might have to be allocated to reduce the risk. If the building is unoccupied, it should not be occupied until the risk has been reduced. If the building is occupied, urgent action should be taken.
Intolerable	Building (or relevant area) should not be occupied until the risk is reduced.

Fire Risk Assessment Review

Assessments should be kept under constant review, and in any case reviewed whenever circumstance change which affect the validity of the current assessment. Whilst there is no maximum period between assessments, it is recommended that the review period should not exceed 12 months.

QUESTION	SIGNIFICANT FINDINGS / ACTION PLAN	RESPONSIBLE PERSON	TARGET DATE	DATE COMPLETED & INITIAL
7.00	ELECTRONIC SOURCES OF IGNITION (Clause 13 and Annex B)			
7.01	If there is not reasonable measures, tick NO and add recommendations of what action should be required here. Example 1: Combustible storage should be a safe separation distance of ½ metre or more from an electrical appliance. Example 2: Electrical intake should be enclosed into a 30 minute fire resisting enclosure. Example 3: Combustible or flammable storage should be prohibited from the electrical intake room and managed regularly to be kept sterile at all times as recommended in the Home Office good practice fire guides. Example 4: Electrical equipment should be switched off when not in use and at the end of the working day. If YES or N/A delete control measure.			
7.02 a)	Introduce a programme of inspection and tests by a competent electrician to the current EICR certificate.			
7.02 b)	Consider having portable electrical appliances tested yearly by a competent person to reduce the risk of electronic sources of ignition.			
7.02 c)	Consider having personal portable electrical appliances tested by a competent person.			
7.02 d)	Provide one electrical socket for each electrical appliance and appoint a competent contractor to carry out any required installation work.			
8.00	SMOKING (Clause 13 and Annex B)			
8.01	Introduce a safe smoking policy in designated smoking areas and enforce prohibiting smoking elsewhere.			
8.02 a)	Enforce the prohibition of smoking in the premises.			
8.02 b)	Introduce a safe smoking policy in designated smoking areas and enforce prohibiting smoking elsewhere.			
8.02 c)	Introduce a safe smoking policy in designated smoking areas and enforce prohibiting smoking elsewhere.			
8.02 d)	Evidence of covert smoking was seen at the back of the premises (used cigarette filters) close to fire exit 8. Ensure all staff are aware this is unacceptable and smoking or vaping should only be performed in designated smoking areas.			
9.00	ARSON (Clause 13 and Annex B)			
9.01	Have a security specialist advise on additional precautions to avoid the risk of arson.			

QUESTION	SIGNIFICANT FINDINGS / ACTION PLAN	RESPONSIBLE PERSON	TARGET DATE	DATE COMPLETED & INITIAL
9.02	Remove or relocate any fire load in close proximity to the premises and control access for ignition by outsiders?			
10.00	PORTABLE HEATERS, HEATING AND VENTILATION SYSTEMS (Clause 13 and Annex B)			
10.01	Ban the use of portable heaters in the workplace and adjust fixed heating accordingly.			
10.02	Arrange for heating and ventilation system to be maintained by a competent contractor.			
11.00	COOKING (Clause 13 and Annex B)			
11.01	Maintain safe separation distance between appliances and flammable/combustible materials.			
11.02	Grease filters and clean ductwork should have maintenance on a regular basis to reduce the risk of fire.			
12.00	LIGHTNING (Clause 13 and Annex B)			
12.01	Provide suitable lightning protection system to building in accordance with BS EN 62305-1:2011.			
13.00	HOUSEKEEPING (Clause 13 and Annex B)			
13.01	Ensure a programme is introduced to improve housekeeping.			
13.02 a)	Maintain safe separation distance of ½ metre between appliance and combustible storage.			
13.02 b)	External bin waste or internal storage should be managed to a higher standard and checked on regular intervals.			
14.00	HAZARDS INTRODUCED BY OUTSIDE CONTRACTORS AND BUILDING WORKS (Clause 13 and Annex B)			
14.01	Impose appropriate fire safety conditions on outside contractors.			
14.02 a)	Introduce a safe system of work for contractors who carry out work within the workplace.			
14.02 b)	Introduce a hot work permit system.			
14.02 c)	Introduce a permit to work system for in-house maintenance workers who carry out 'hot work' involving processes such as welding or flame cutting.			
15.00	DANGEROUS SUBSTANCES (Clause 13)			
15.01	Examples: Reduce the quantity of dangerous substances to a minimum. Ensure that any release of a dangerous substance which may give rise to risk is suitably collected, safely contained, removed to a safe place, or otherwise rendered safe, as appropriate. Avoid ignition sources including electrostatic discharges. Arrange a DSEAR risk assessment by a competent contractor and reviews should be made regularly, especially when there is a significant change in use of substances or quantities.			
16.00	OTHER SIGNIFICANT FIRE HAZARDS THAT WARRANT CONSIDERATION			

QUESTION	SIGNIFICANT FINDINGS / ACTION PLAN	RESPONSIBLE PERSON	TARGET DATE	DATE COMPLETED & INITIAL
16.01	List and detail any other significant hazards here if applicable?			
17.00	MEANS OF ESCAPE (Clause 15c) and Annex C)			
17.01	Improve the means of escape in as follows:			
17.02 a)	Increase the width of the escape corridors to 1.2 metres.			
17.02 b1)	Provide a pass door in the following locations: #add locations#. Provide external fire escape in the following location # add location#. Provide an additional exit to the escape corridor from the inner room #add location#.			
17.02 b2)	Provide external fire escape in the following location # add location#. Provide an additional exit to the escape corridor from the inner room #add location#.			
17.02 c)	Provide additional escape exits in the following locations #add location#.			
17.02 d)	Re-hang and recess the door to #add location# to open in the direction of escape.			
17.02 e)	Provide pass final exit doors adjacent to revolving or sliding doors in the following locations #add locations#.			
17.02 f)	Reduce the securing devices on final exit doors to a single device provided with a suitable sign on how to operate.			
17.02 g)	Repair or replace damaged partitions to the required fire resisting rating including 1.8m (England & Wales) or 2.0m (Scotland) rule to external staircases.			
17.02 h)	Train fire marshals in how to use evac chairs provided/place in safe refuge such as fire rated staircase enclosure/relocate such workers or visitors to ground floor accommodation only. Provide evacuation lifts or fire lifts used to evacuate disabled people from upper floors. Provide a suitable refuge within the staircase enclosure in the following locations: Ensure communication equipment in refuge is tested regularly as required.			
17.03	Make sure escape routes are clear and ready for immediate use at any time.			
17.04 a)	The following fire doors have gaps between door and frame. Provide self closing devices to the following doors. The following doors have damage. Installations and maintenance should be actioned by a 3rd party accredited and competent contractor and must comply to the manufacturer recommendations or BS 8214:2016.			
17.04 b)	Arrange a competent contractor to survey and complete required works.			
17.04 c)	Clear internal or external storage.			

QUESTION	SIGNIFICANT FINDINGS / ACTION PLAN	RESPONSIBLE PERSON	TARGET DATE	DATE COMPLETED & INITIAL
17.04 d)	Remove one of the two securing devices from the final exit door from the #add location#. Install suitable interlocks on doors normally kept close for security reasons in the following locations: #add locations#. Provide a panic bolt/latch and appropriate sign on the final exit door from #add location#.			
18.00	MEASURES TO LIMIT FIRE SPREAD AND DEVELOPMENT (Clause 15g)			
18.01 a)	Repair or replace damaged compartment walls to the required fire resisting rating. Repair or replace damaged compartment floors or ceilings to the required fire resisting rating.			
18.01 b)	Replace furniture that is damaged/perished as they are a fire hazard. Reduce risk by removing, covering or treating large areas of flammable wall and ceiling linings to reduce the rate of flame spread across the surface.			
18.02	Have a survey actioned by a fire damper competent contractor.			
19.00	EMERGENCY ESCAPE LIGHTING (Clause 15e)			
19.01	Provide emergency lighting to illuminate internal and external escape routes and points of emphasis.			
20.00	FIRE SAFETY SIGNS AND NOTICES (Clause 15d)			
20.01	Provide green moving person signs with appropriate directional arrows to indicate the secondary escape routes in the following locations: #add locations#.			
21.00	MEANS OF GIVING WARNING IN CASE OF FIRE (Clause 15b)			
21.01	Install an electrical fire alarm system conforming to BS 5839. Install a fire control panel that can be seen from the outside through an entrance to the building. Install a fire control repeater panel linked to the existing system on an external wall. Provide additional fire alarm call points linked into the existing system in the following locations: #add location#			
21.02	Install an auto-dialler device to inform an alarm receiving centre of a fire alarm activation via a secure telephone line.			
21.03	Consider providing a zone plan of the system adjacent to the fire control panel.			
21.04	Reduce false alarms by replacing smoke detector with a heat detector in the kitchen.			
22.00	MANUAL FIRE EXTINGUISHING APPLIANCES (Clause 15f)			

QUESTION	SIGNIFICANT FINDINGS / ACTION PLAN	RESPONSIBLE PERSON	TARGET DATE	DATE COMPLETED & INITIAL
22.01	Replace the non standard fire extinguishers with BS/LPC approved extinguishers in the following locations.			
22.02 a)	Add portable fire extinguishers.			
22.02 b)	Remove hose reels and replace with modern portable extinguishers.			
22.02 c)	Add fire blankets in the kitchen.			
22.03	Remove obstructions in the following places:			
23.00	RELEVANT AUTOMATIC FIRE EXTINGUISHING SYSTEMS (Clause 15h)			
23.01 a)	Install sprinkler system if required and reasonably practicable due to life risk.			
23.01 b)	Install misting system if required and reasonably practicable due to life risk.			
23.01 c)	Install kitchen suppression system if required and reasonably practicable due to life risk.			
23.01 d)	Install gas flooding system if required and reasonably practicable due to life risk.			
24.00	OTHER RELEVANT FIXED SYSTEMS AND EQUIPMENT (Clause 15i)			
24.01	Provide a system of roof ventilators, activated by automatic fire detectors and sub-divide roof into appropriate smoke reservoirs.			
24.02	Install isolation device and inform fire authority that neon signs are installed so it can be logged on IRS.			
24.03	Install isolation device on solar panels and inform fire authority so it can be logged on IRS.			
25.00	PROCEDURES AND ARRANGEMENTS (Clause 16)			
25.03	Review fire emergency plan to detail required fire safety arrangements.			
25.04	Formulate and document fire procedures for the premises.			
25.04 a)	Make arrangements for investigating fire alarm signals.			
25.04 b)	Ensure that the plan provide clear instructions on procedures for liaising with the fire brigade on arrival.			
25.04 c)	Ensure that the plan gives clear instructions of any special risks on the premises.			
25.04 d)	Ensure that there are suitable arrangements for ensuring that the premises have been evacuated.			
25.04 e)	Ensure that there a suitable fire assembly point(s).			
25.04 f)	Ensure that there adequate PEEPs or GEEPs for the evacuation of any disabled people who are likely to be present.			
25.05	Nominate persons to be trained to use fire extinguishing appliances.			
25.06	Ensure fire emergency plan covers multiple occupied premises.			
25.07	Nominate persons to assist with evacuation of disabled people.			

QUESTION	SIGNIFICANT FINDINGS / ACTION PLAN	RESPONSIBLE PERSON	TARGET DATE	DATE COMPLETED & INITIAL
25.08	Arrange for the local fire and rescue service to carry out pre-fire inspections of the premises.			
25.09	Ensure that all required routine fire inspections are carried out.			
26.00	TRAINING AND DRILLS (Clause 16h)			
26.01	Introduce an appropriate induction training presentation for the workplace.			
26.01 a)	Arrange induction training for all new staff.			
26.01 b)	Arrange periodic training for all staff on fire awareness.			
26.01 c)	Arrange additional training for staff with specific roles.			
26.01 d)	Add content to existing training as follows:			
26.02	Arrange fire drills for every six months for the building occupiers. Ensure out of hour workers also participate in additional fire drills every six months.			
26.03	Provide other employees staff with information, instruction or training on the fire safety measures on the premises.			
27.00	TESTING AND MAINTENANCE (Clause 16j)			
27.01	Ensure that checks, inspections and maintenance are carried out at appropriate intervals.			
27.02	Senior fire marshal to ensure that weekly fire alarm test and periodic servicing are carried out and recorded by competent persons.			
27.03	Senior fire marshal to ensure that monthly and annual emergency lighting tests are carried out and recorded by competent persons.			
27.04	Ensure that monthly checks, and annual maintenance of portable fire fighting appliances are carried out and recorded by competent persons.			
27.05	Arrange the periodic inspection of external escape staircase and gangways.			
27.06	Arrange six-monthly inspection and annual pressure testing of dry riser.			
27.07	Arrange weekly and monthly testing, six monthly inspection and annual testing of fire-fighting or evacuation lifts.			
27.08	Arrange periodic testing for sprinkler system by a competent person.			
27.09	Arrange routine checks of final exit doors and security fastenings.			
27.10	Arrange the annual inspection of lightning protection system.			
27.11	Ensure that periodic inspections of Inergen/FM200/Argonite total flooding/local application system are carried out and recorded by competent persons.			
28.00	RECORDS (Clause 16k)			
28.01 a)	Provide and maintain a register of records for fire drills.			
28.01 b)	Provide and maintain a register of records for fire training.			
28.01 c)	Provide and maintain a register of records for fire alarm tests.			
28.01 d)	Provide and maintain a register of records for false alarms.			
28.01 e)	Provide and maintain a register of records for emergency lighting tests.			

QUESTION	SIGNIFICANT FINDINGS / ACTION PLAN	RESPONSIBLE PERSON	TARGET DATE	DATE COMPLETED & INITIAL
28.01 f)	Provide and maintain a register of records for fixed fire system tests.			
28.01 g)	Review and add more relevant detail to the fire emergency plan.			

PHOTOGRAPHS - (reference to index number of action)

To add page breaks after each page:

<Page Layout>

<Breaks>

<Insert Page Break>

To remove page breaks:

<Page Layout>

<Breaks>

<Reset all page breaks>