

The control of legionella in hot & cold water systems

System 4 Site Services

Sentinel outlets temperature checks (first & last tap)

1. Water heater temperature (minimum 60°C)
2. Hot water delivery temperature at the tap or inlet side of TMV within 1 minute (minimum 50°C)
3. Flush the cold water until the temperature stabilizes and is comparable to supply water at the tap outlet or inlet side of the TMV (maximum 20°C)
4. Record the blended outlet temperature if supplied by TMV (38°C - 41°C)

	Temperature
1.	
2.	
3.	
4.	

Pressure Wash Compound

1. Flush the cold water until the temperature stabilizes and is comparable to supply water (maximum 20°C)

	Temperature
1.	

Infrequently used outlets

Press and hold the light switch located at the left hand side of the vehicle wash facility for 5 seconds and this will activate the water test facility for 1 minute

OK	
----	--

Date: _____

Signature: _____