

Distribution Board

Carry out Inspection & Testing to comply with the 'Electricity at Work Regulations 1989'. Inspection & Testing to comply with BS 7671:2001

Certificates located in the Facilities & Maintenance Department PE Filing Cabinet 'C'

The Report, normally comprises at least four pages, shall include schedules of both the inspection and the test results. Additional sheets of test results may be necessary for other than a simple installation. The page numbers of each sheet shall be indicated, together with the total number of sheets involved

Certificates required for recording results:

Form 3: Schedule of Inspections

Form 4: Schedule of Test Results

Form 6: Periodic Inspection Report of an Electrical Installation

On completion of schedule ensure that equipment is functioning correctly including all safety equipment