

# SPECIFICATION:

TOTAL NUMBER OF PROPERTIES: 20

LPG STORAGE: 3 x 4000 LITRE UNDERGROUND STORAGE VESSELS (FOR DETAILS REFER TO CALOR DRAWING 1B614).

ALL CIVIL WORK INCLUDING TRENCHES AND EXCAVATION TO BE CARRIED OUT BY CLIENTS CONTRACTOR.

PIPE SIZE BASED ON A MAXIMUM LOAD OF 30 KWH PER PROPERTY.

SUPPLY PRESSURE 75 MBAR.

MINIMUM SYSTEM PRESSURE OF 65 MBAR.

MAXIMUM GAS VELOCITY < 20 m/s.

APPROXIMATE AMOUNT OF 90mm PE80 REQUIRED - 50m

APPROXIMATE AMOUNT OF 63mm PE80 REQUIRED - 150m

APPROXIMATELY 10m OF 25mm PE80 PER SERVICE

1 x 63mm HEAVY DUTY ISOLATION BALL VALVE

20 OFF 63x32 TOP TAPPING TEES AND FLOW LIMITERS

METER BOXES TO BE SEMI-SUBMERGED TYPE AND INSTALLED BY APPROVED CALOR CONTRACTOR (FINAL LOCATIONS TO BE CONFIRMED).

FIRST STAGE PRESSURE REDUCING MODULE TO BE SUPPLIED BY CALOR AND INSTALLED BY APPROVED CALOR CONTRACTOR (FINAL LOCATION TO BE CONFIRMED).

SECOND STAGE PRESSURE REDUCING MODULE TO BE SUPPLIED BY CALOR AND INSTALLED BY APPROVED CALOR CONTRACTOR (FINAL LOCATION TO BE CONFIRMED)

Trench Detail: LPG mains & service pipework, minimum operating pressure 75mbars

| Pipe Location  | Min. depth of cover |
|----------------|---------------------|
| Public Highway | 1.0m                |
| Private Road   | 0.75m               |
| Footpath       | 0.5m                |
| Open Land      | 0.4m                |




Bed of other fine material to be used as bedding around gas pipe

As detailed above, gas pipe to be installed in trench & covered with bedding material at bottom of trench

| Trench cover, minimum depth | Min. depth of cover |
|-----------------------------|---------------------|
| 1.0m                        | 0.75m               |
| 0.75m                       | 0.5m                |
| 0.5m                        | 0.4m                |

Trench detail: trench with other services detail



As detailed above, gas pipe to be installed in trench & covered with bedding material at bottom of trench


As detailed above, gas pipe to be installed in trench & covered with bedding material at bottom of trench

| Trench cover, minimum depth | Min. depth of cover |
|-----------------------------|---------------------|
| 1.0m                        | 0.75m               |
| 0.75m                       | 0.5m                |
| 0.5m                        | 0.4m                |

Shows unit No + Position of  
Rat and Semi recessed meter box.

Shows proposed route of main  
This is then in management land which  
Saves access across gardens etc. and keeps away  
from buildings.

Tanks Rotated through 90°



El Sub Sta

90mm  
65mm  
REDUC

calor gas tanks

sewage treatment plant


## REFERENCES

PN 1751

UNLESS OTHERWISE STATED:-

ALL DIMENSIONS IN MILLIMETRES.

ALL STANDARDS ARE TO LATEST ISSUE.



PRIVATE & CONFIDENTIAL

THIS DRAWING IS THE PROPERTY OF CALOR GAS AND MUST NOT BE  
COPIED OR REPRODUCED WITHOUT THE PERMISSION OF THE COMPANY.

PROPOSED GAS LAY OUT  
AT ROCK LANE FARM  
METERED ESTATE

CALOR GAS  
Athena Drive Warwick CV34 6RL

DATE 08/08/06

DRAWN C.C.

TRACED

CHECKED

SCALE 1-250

DRG. SIZE A1

ISSUE A

DRG. No.  
19321