

Oxmaint AI — Data Center FSM Portal

Data Gap Assessment & Action List

Reviewed at: oxmaint.ifactoryai.com/portal/datacenter/overview — every module in the sidebar, checked for record count against what the SOW and the portal's own pages imply it should hold. This document lists the modules that are thin on data, ranked by how much they affect the PoC's Go/No-Go read, and points to the companion workbook (Oxmaint_Portal_Gap_Fill_Data.xlsx) that supplies data to close the top gaps.

Reviewed: 25 Aug 2026 · Portal state: Illustrative PoC data, 6 sites, 46 assets in scope

1. Modules to add data to — ranked by priority

"Priority" here means how much the gap limits what the portal can currently prove — not just how empty a page looks.

1. Site Readiness

Current: 0 of 15 items

Priority: Critical

All items "Not Started"

This is the single biggest open gate on the Go/No-Go page. None of the 15 SOW 5.2 prerequisites (site access, safety induction, CMMS export, as-builts, network drops, etc.) show any progress. Add status updates as each item is actually cleared with the client — this can't be synthesized, it has to be tracked as it happens.

2. Technical Prerequisites

Current: 0 of 12 items

Priority: Critical

All items "Not Started"

Same issue as Site Readiness, for the network/cybersecurity/power prerequisites. Together these two make up the "0 of 27" the Go/No-Go page leads with.

3. Analytics & Monitoring (Fleet Monitoring, Trend Analysis, Detections, Recommendations)

Current: 3 of 46 assets

Priority: High

Only CRAH-01, CRAC-01, Chiller-01 (all IAD35) have any monitoring data

This is the demo-facing heart of the portal, and 43 of 46 in-scope assets show nothing here. The companion workbook adds vibration/thermal/ultrasound readings, detections, recommendations and work orders for 10 more assets (7 anchored to existing register alerts, 3 fresh for lifecycle variety) — anchored values match the alert readings already on the site, so nothing added contradicts what's there.

4. Outcome Log

Current: 1 closed record

Priority: High

Alert Accuracy and False Positive Rate KPIs computed over a single data point

The page itself flags this: "a single outcome moves each figure by 100 points." The companion workbook's Outcome_Log_Additions sheet adds 5 more closed outcomes (4 true positive, 1 false positive) plus 2 more open ones — enough to make the accuracy figures mean something.

5. Condition Monitoring → Sensor Readings

Current: 14 readings

Priority: Medium

Single before/at-alarm/after-repair snapshots per alert, not a continuous stream

Reads as event log rather than condition monitoring. The new Sensor_Readings_Daily sheet turns each of these snapshots into a full 30-day daily trend, which is also what Trend Analysis needs to plot a line rather than three dots.

6. Integrated Sources → BMS / EPMS / DCIM / OEM / Battery Telemetry

Current: 8–14 readings each

Priority: Medium

Same snapshot-only pattern as Sensor Readings

Lower priority than the condition-monitoring sensors because these are existing systems being read, not the new PoC instrumentation — but still thinner than "telemetry" implies. Worth a top-up once the higher-priority gaps are filled, using the same anchor-and-interpolate approach.

7. Inspection → Incident Reports

Current: 7 incidents

Priority: Low

This is the pre-PoC baseline the whole "early detection" story is measured against

Not necessarily wrong — 7 may be everything the client's records contain — but worth confirming with Digital Realty whether more historical incidents exist before treating 7 as the final denominator.

2. Modules that are already well populated

No action needed here — listed for completeness so the priority list above reads as a gap list, not a full audit.

Module	Current volume
Site Master	6 of 6 sites
Location Hierarchy	36 locations
Assets Master	48 assets (46 in scope)
Asset Classes	20 classes
Inspection Reports	49 inspections
Inspection Reminder	49 reminders
Checklist	3 checklists / 25 items
Alert & Anomaly Register	8 alerts
Maintenance Correlation Log	7 correlations
KPI Dashboard	10 KPIs computed
Weekly Health Report	8 reports
Benefits Realization	6 benefits recorded
Data Source Systems	11 systems
Work Orders	10 work orders
PM Task Library	25 tasks / 20 asset classes
PM Compliance	10 logs
Risk Register	10 entries (6 risks, 2 assumptions, 2 dependencies)
Stakeholders & RACI	8 roles
Failure Codes	17 (matches SOW 4.2-4.4 exactly)
Criticality Matrix	4 tiers
Manufacturers	20 asset classes covered

3. What's in the companion workbook

Oxmaint_Portal_Gap_Fill_Data.xlsx extends condition monitoring from 3 assets to 10, covering all 8 alerts already in the Alert & Anomaly Register, plus 3 fresh assets added purely for lifecycle variety. Every anchored value matches a reading or alert already on the site, so adding this data does not contradict anything already there.

Sheet	What it adds
New_Monitored_Assets	10 new assets and which sensors/failure mode/status each one carries. 7 are cross-referenced to an existing register alert; 3 (AHU 01 ORD12, Cooling Tower 01 IAD35, UPS System 01 LHR10) are fresh, not yet in the register.
Sensor_Readings_Daily	585 daily readings across the 10 assets and their applicable sensors, interpolated through the exact values already recorded where an anchor exists, or a fresh 15-day rise for the 3 new assets.
Detections	One row per new asset (10 total): failure code, corroborating sensors, and the confidence-before/confidence-after figures the cross-sensor correlation produces.
Recommendations_WorkOrders	The action each detection produced. Spans every lifecycle stage: Recommended only, Dispatched, Completed, and one Not Raised (false positive) — not just the completed end state.
Outcome_Log_Additions	5 closed outcomes (4 true positive, 1 false positive) and 5 open ones, ready to fold into the Outcome Log's accuracy figures.
Incident_Downtime_Detail	All 7 existing incidents with numeric downtime hours, a qualitative downtime note, description and root cause — the data source for the requested downtime chart on the incident detail page.

Anchored assets: IAD35-PUMP-01, ORD12-UPS-01, LHR10-LVSG-01, FRA15-XFMR-01, SIN11-GENS-01, SYD12-CHIL-01, ORD12-PDU-01 — each already has an alert in the register (ALT-0001 through ALT-0008). Fresh assets: ORD12-AHU-01, IAD35-CTWR-01, LHR10-UPS-01 — new detections in early lifecycle stages (Recommended / Dispatched), added so the Recommendations screen has more than one status to show.

Not covered by synthetic data: Site Readiness and Technical Prerequisites (items 1 and 2 above). These track real client/vendor actions — network access granted, safety induction completed, approvals signed — and shouldn't be backfilled with fabricated status. They need to be updated as the actual PoC mobilization work happens.

4. Feature requests raised during this review

Three items below are UI/feature requests, not data gaps — flagged here so the dev team has them alongside the data work above. The data each one needs already exists or has been added.

Incident Reports — detail page

Priority: **Medium**

On opening an incident, show a downtime chart and a clear description of the failure and root cause, rather than leaving those as plain text fields.

Data need: none — every incident already has Downtime_Hours, Description and Root_Cause. The companion workbook's new Incident_Downtime_Detail sheet lays these out pre-cleaned (numeric downtime + a separate qualitative note) specifically so a chart can be built directly off it.

Analytics & Monitoring — “Fleet Monitoring” naming

Priority: **Low**

Rename to something more relatable to data center operations (e.g. “Asset Condition Overview” or “Live Asset Health”) and add more assets to it.

Data need: covered — the companion workbook takes monitored assets from 3 to 10 (see Section 3). The rename itself is a label change on the existing page, no new data required.

Trend Analysis — chart zoom

Priority: **Low**

The chart is too tightly zoomed on the alarm crossing; zoom out so the reader sees more of the quiet baseline period around it.

Data need: none — this is a chart axis/scaling change on the existing 30-day series. All three newly-added trend assets (Section 3) already carry a full quiet baseline before the rise, so the wider view will have data to show once the axis is adjusted.

Detections and Recommendations & Work Orders — data added this pass

Both were flagged as needing more data. The companion workbook now carries 10 detections total (7 anchored to existing register alerts, plus 3 fresh ones — Air Handling Unit 01 ORD12, Cooling Tower 01 IAD35, and UPS System 01 LHR10 — added purely for lifecycle variety) and 10 matching recommendation/work-order rows spanning every stage: Recommended only, Dispatched, Completed, and one False Positive outcome. That covers the full stepper shown on the Recommendations & Work Orders screen, not just the “Completed” end state.