

TWO 356

BILL

WATER QUALITY TESTING LABORATORY

W/S & Sanitation (R.W.S.) Branch
Amritsar.

Book No.

Bill No. 7286

To Vivek Public School
Village: Heir Ajnala Road
ASR

Date 30.3.2021

Your Ref. N/A

Date 26.03.2021

No. of Samples	Type of Analysis	Rate	Amount
472	Physical / Chemical / Bacteriological Analysis of water.	150	150
	Name of Scheme : PROV / OPR		
	Sieve Analysis of Sand Sample		
	RUPEES One hundred fifty only		

Incharge

Assistant Chemist :

HI Tech Multi District Water Testing Laboratory.
Water Supply & Sanitation Complex,
Near Jaura Phatak Amritsar.

472

**ANALYSIS REPORT FOR THE PHYSICAL & CHEMICAL AND BACTERIOLOGICAL
EXAMINATION OF THE WATER SAMPLE**


Particulars of Sample

1. Name of the Place: *Vinik Public School, Main Block: ASR*
2. Source of the sample: *S/imp (400')*
3. Whether water chlorinated: *—*
4. Date of Collection: *26-3-21*
5. Name and designations of the officer who collected Sample: *Principal*
6. Date and Time of Commencing of Examination: *30-3-21*

CHEMICAL TEST REPORT

No.	TEST	DESIRABLE LIMIT	PERMISSIBLE LIMIT	RESULT
1	Turbidity (NTU)	5.0	10	<i>0.1</i>
2	Color (Physically)			<i>2.2</i>
3	pH	6.5 to 8.5	No Relaxation	<i>7.2</i>
4	Total Dissolved Solids, PPM	500	2000	<i>277</i>
5	Alkalinity (as calcium carbonate) mg/L	200	600	<i>210</i>
6	Total Hardness (as Ca Co) mg/L	200	600	<i>200</i>
7	Residual Chlorine mg/L	0.2	1.0	<i>—</i>
8	Iron mg/L	0.3	No Relaxation	<i>0.01</i>
9	Flourides (as F) mg/L	1.0	1.5	<i>—</i>
10	Nitrate (as NO ₃) mg/L	45	No Relaxation	<i>—</i>
11	Bacteriological Examination	After 24 hrs to 48 hrs		<i>/</i>
	Total Coliform			
	E.Coli			

The water is Potable/ ~~Not Potable~~ according to the parameter tested above.


 Chemist
 HI Tech Multi Distt.
 Water Testing Laboratory
 Deptt. Of W/S & Sanitation,
 Amritsar.

1. Sample is not drawn by us unless otherwise stated.
2. Sample consumed in Testing.