

## Regenerative Rankine cycle

A simple Rankine cycle is modified with regeneration. Assume the mass flow rate through the boiler does not change. How does the turbine work output change?

Answer: It decreases.

Explanation: The steam that is used for the feed water heating is extracted from the turbine and cannot produce work anymore in the turbine.