

## Regenerative Rankine cycle

A simple Rankine cycle is modified with regeneration. Assume the mass flow rate through the boiler does not change. How does the moisture content at the turbine exit change?

Answer: It remains the same.

Explanation: The moisture content at the turbine exit is not influenced by the mass flow. It only depends on the properties of the fluid at the turbine exit (pressure, temperature).