

Effect outside temperature on COP

The lower the outside temperature is, the lower the COP since it requires higher power from the compressor to lift the refrigerant to the required temperature and pressure. Generally:

$$\text{COP} = \frac{Q_H}{P_{\text{compressor}}}$$

The higher the power the lower the COP