

Regenerative Rankine cycle

A simple Rankine cycle is modified with regeneration. Assume the mass flow rate through the boiler and the temperature at the turbine inlet does not change. How does the heat input in the boiler change?

Answer: It decreases.

Explanation: As the feed water is preheated by steam extracted from the turbine less heat need to be supplied to the boiler.