

Improving efficiency

Which of the following actions contributes to the improvement of efficiency of Rankine cycle in a Thermal Power Plant?

Answer: All answers are correct.

Explanation: The regenerative features effectively raise the nominal cycle heat input temperature, by reducing the addition of heat from the Boiler/fuel source at the relatively low feedwater temperatures that would exist without regenerative feedwater heating.