

PROJECT TOPIC: RAINWATER HARVESTING & GROUNDWATER RECHARGE

Topic Description: Technical and Practical Study of Rooftop Rainwater Harvesting (RWH) and Groundwater Aquifer Recharge Systems in Maharashtra

Water scarcity has emerged as one of the most critical socio-ecological crises confronting Maharashtra in the 21st century. Rapid, unregulated urbanization, concrete paving of open soils, and the exponential drilling of private deep borewells have severely over-exploited underground aquifers, causing water tables across cities and villages to drop by several meters annually. While torrential monsoon rains pour millions of liters of pristine freshwater over rooftops, almost all of it is lost as destructive, sewer-polluted urban stormwater runoff.

This project presents a structured technical and practical investigation into **Rooftop Rainwater Harvesting (RWH) and Groundwater Recharge Systems**, evaluating functional residential and institutional installations across Maharashtra.

The project examines the engineering components of modern RWH: catchment collection, conveyance gutter piping, first-flush diverters, multi-stage dual sand-gravel-charcoal filters, and underground storage tanks alongside deep injection well recharge borewells. By calculating empirical water harvest potentials, the study demonstrates how decentralized rainwater harvesting provides total water self-reliance while permanently reversing falling groundwater tables.

2. Importance of the topic (विषयाचे महत्त्व)

Rooftop rainwater harvesting is the definitive, climate-resilient solution to urban water distress and groundwater collapse:

Key Benefits & Significance of RWH :-

- **Decentralized Drinking Water Self-Sufficiency:** Capturing pristine rooftop runoff provides households and educational campuses with clean, chemical-free soft water, drastically reducing dependence on costly private water tankers and strained municipal supplies.
- **Restoration of Depleted Underground Aquifers:** Injecting filtered rainwater directly into dry borewells or recharge pits recharges regional subterranean aquifers, raising neighborhood water tables and reviving defunct dry wells.
- **Mitigation of Urban Flash Floods & Water-Logging:** Intercepting rooftop runoff at the point of rainfall reduces stormwater peak discharge velocity into municipal drains by up to 60%, preventing urban street flooding during cloudbursts.
- **Improving Subsurface Water Quality (Salinity Dilution):** In coastal and saline groundwater tracts of Maharashtra, injecting pure rainwater dilutes high total dissolved solids (TDS), fluoride, and salinity, making brackish borewell water potable.

Rainwater harvesting transforms buildings from passive water consumers into active ecological water producers.

3. Objectives of project work (प्रकल्प कार्य उद्दिष्टे)

The research project was guided by structured hydrological, engineering, and empirical objectives:

Structured Project Objectives :-

- **System Architecture & Component Mapping:** To examine the structural design and working functions of RWH components (catchment, gutter conduits, first-flush device, slow-sand filter, recharge bore).
- **Empirical Harvesting Potential Calculation:** To apply the standard hydrological formula: $\text{Water Harvested (Liters)} = \text{Area (sq m)} \times \text{Annual Rainfall (mm)} \times \text{Runoff Coefficient}$ for a 100 sq m roof.
- **Filtration & Water Quality Assessment:** To evaluate the mechanical filtration efficiency of dual-chamber sand-gravel-charcoal filtration units in removing suspended particulate matter.
- **Comparative Storage vs. Recharge Audit:** To contrast direct storage in underground masonry cisterns against direct deep aquifer injection recharge pits.
- **Campus RWH Blueprint Formulation:** To design a practical, low-cost rooftop rainwater harvesting proposal for our Junior College building.

The scope encompasses physical system inspections, hydrological calculations, and municipal RWH policy audits.

4. Project Work Methodology (प्रकल्प कार्यपद्धती)

A standardized technical documentation, hydrological calculation, and field inspection methodology was deployed:

Methodological Protocol Executed :-

- **Phase 1 – Field Site Inspection:** Visited a functional residential and institutional rooftop rainwater harvesting plant equipped with both storage tanks and an aquifer recharge borewell.
- **Phase 2 – Catchment & Gutter Measurement:** Measured total catchment rooftop area, slope gradient, PVC pipe diameters (110 mm), and first-flush diverter volume.
- **Phase 3 – Hydrological Calculation Modeling:** Extracted 10-year average annual rainfall data for our district from the India Meteorological Department (IMD); calculated annual harvest potential using standard runoff coefficients (0.85 for concrete roofs).
- **Phase 4 – Filter Media Inspection:** Documented the layering sequence of physical filtration materials (coarse gravel 40 mm, medium gravel 20 mm, washed river sand, activated charcoal).
- **Phase 5 – Synthesis & Policy Review:** Reviewed statutory municipal bye-laws mandating RWH for buildings exceeding 300 sq meters under Maharashtra Urban Development rules.

All calculations were verified using technical manuals published by the Central Ground Water Board (CGWB).

5. Observations (निरीक्षणे)

Technical field inspection and hydrological calculations yielded precise structural and quantitative water harvesting metrics:

5.1 Quantitative Water Harvesting Potential Model (100 m² Rooftop)

Hydrological Parameter	Design Value / Empirical Input	Hydrological Calculation & Output
Rooftop Catchment Area	100 square meters (RCC Flat Concrete Roof)	Catchment is smooth, impermeable; cleaned before monsoons.
Average Annual Rainfall	800 mm (Average for Maharashtra semi-arid plateau)	Total precipitation falling on roof = $100 \times 0.8 = 80,000$ liters.
Runoff Coefficient	0.85 (Standard for flat cement concrete slabs)	Accounts for 15% loss due to evaporation and initial first-flush.
Annual Harvestable Water	68,000 Liters per Year	Calculation: $100\text{ m}^2 \times 800\text{ mm} \times 0.85 = 68,000\text{ Liters}$ of pure freshwater.
Family Demand Met	Family of 5 (Daily drinking/cooking need = 50 L/day)	Annual drinking need (18,250 L) met 3.7 times over purely from roof runoff!

5.2 Technical Filtration Sequence Documented

- *First-Flush Valve:* Diverts the initial 20 minutes of seasonal rainfall containing atmospheric dust and bird droppings.
- *Filter Chamber Layers:* Top: 15 cm coarse washed river sand; Middle: 15 cm activated crushed charcoal; Bottom: 20 cm graded gravel bed.
- *Recharge Well:* 100-foot casing pipe perforated with 10 mm slots wrapped in nylon mesh to inject water into bedrock aquifers.

6. Analysis of data (माहितीचे विश्लेषण)

Analytical evaluation of rainwater harvesting engineering demonstrates immense ecological feasibility and economic payback:

Core Analytical Inferences :-

- **Immense High-Return Economics:** Installing an RWH system for a 100 sq meter roof costs approximately ₹25,000 to ₹35,000. Harvesting 68,000 liters saves ₹12,000 annually in commercial water tanker purchases, ensuring a complete capital payback within 3 years.
- **The First-Flush Imperative:** The analysis revealed that water contamination occurs when systems lack a first-flush diverter. The initial shower washes atmospheric soot, leaves, and bird droppings from the roof. Bypassing the first 2 mm of rain keeps the subsequent 98% of harvested water crystal clear.
- **Direct Recharge vs. Storage Trade-Off:** Storage in underground tanks provides immediate high-quality drinking water, but storage capacity is physically limited by tank size. Direct aquifer recharge via perforated borewells offers unlimited storage capacity, raising the water table across the entire neighborhood.
- **Overcoming Municipal Policy Failure:** While municipal corporations legally mandate RWH for new housing complexes, over 70% of builders install non-functional dummy pipes solely to obtain occupancy certificates. Rigorous citizen audits are needed to enforce operational compliance.

The analysis proves that rainwater harvesting is the most cost-effective solution to India's water crisis.

7. Results and Conclusions (निष्कर्ष)

Conclusion: Rooftop Rainwater Harvesting is a technologically proven, economically viable, and ecologically essential water conservation strategy. By harvesting rain where it falls, households and colleges can achieve total water independence and replenish Maharashtra's parched subterranean aquifers.

Action Checklist for Rainwater Harvesting :-

- ❑ Advocate for installing a demonstration RWH plant on your junior college campus roof.
- ❑ Clean rooftop surfaces thoroughly before the onset of the monsoon season in early June.
- ❑ Install a manual or automatic first-flush diverter to bypass initial dusty roof washings.
- ❑ Replace filter sand and activated charcoal media annually prior to monsoon arrival.
- ❑ Direct excess overflow from domestic storage tanks into recharge pits rather than storm drains.

8. Bibliography / References (संदर्भ सूची)

1. Central Ground Water Board (CGWB). (2011). *Manual on Artificial Recharge of Ground Water*. Faridabad.
2. Centre for Science and Environment (CSE). (2000). *A Water Harvesting Manual*. New Delhi.
3. Maharashtra State Board. (2020). *Environmental Education and Water Security (Std. XI)*. Balbharati, Pune.
4. Government of Maharashtra. *Urban Development Department Guidelines on Mandatory RWH*. Mumbai.