TELANGANA STATE DISASTER RESPONSE & FIRE SERVICES

Fire No Objection Certificate (Renewal) - Industrial Occupancy

NOC No.: TSFS/HYD/NOC/2026/0457
Date of issue: 15-01-2026
Valid up to: 14-01-2027

Issued to: Shakti Electro-Pack Pvt Ltd (fictional)
Premises: Plot 14, IDA Cherlapally, Hyderabad - 500051 (Site 1)
Occupancy: Industrial - RF module and PCB assembly, G+1, built-up area 2,860 sq m

Conditions

1. Fire extinguishers to be refilled annually and records kept.
2. Hydrant and sprinkler system to be tested every 6 months.
3. Renewal application to be filed at least 30 days before expiry.

Issuing authority: District Fire Officer, Medchal-Malkajgiri, Telangana Fire Services

This is a fictional sample document for a product demo.