

Energy Meters

Location		MCCB	CT	Modbus Address	Coverter IP
P1	PR	400A, 3P	400/5	3	192.168.1.119
	BM Section 1 -ST/TH/MD/TR	630A, 3P	800/5	2	
	BM Section 2 -Vacuum/VAT/CON	400A, 3P	250/5	1	
	STR/COMPRES	400A, 3P	400/5	4	
	GENERATOR	2000A, 4P	2000/5	5	
	P1 -Main Incoming Energy	2000A, 4P	2000/5	29	
	Compressor 1	100A, 3P	100/5	7	192.168.1.155
	Compressor 2	63A, 3P	100/5	10	
	Compressor 3	100A, 3P	100/5	8	
	Compressor 4	100A, 3P	100/5	9	
	Air Dryer	80A, 3P	100/5	6	
	STR	160A, 3P	200/5	11	
P4	P2-PR	400A, 3P	400/5	21	192.168.1.123
	P1-CELLULOSE	160A, 4P	250/5	22	
	OFFICE/WSHOP/CWA	250A, 4P	250/5	23	
	P4- BM	800A, 3P	800/5	24	
	P4- PR	630A,3P	800/5	25	
	P4- STR/TR	160A, 3P	200/5	12	192.168.1.157
	P4-SUB SECTION	400A, 3P	400/5	13	
	P4- BAG OPENER	250A, 4P	250/5	15	
	STRIP CEILLING PLANT	400A, 3P	400/5	14	
	P4- ST/TR	250A, 3P	250/5	16	
	GENERATOR	1600A, 4P	2000/5	17	192.168.1.158
	P4 -Main Incoming Energy	1600A, 4P	2000/5	30	
	Compressor 1	80A, 3P	100/5	26	192.168.1.159
	Compressor 2	60A, 3P	100/5	27	
	Air Dryer	80A, 3P	100/5	28	
Canteen	WORKSHOP	100A, 4P	100/5	18	192.168.1.156
	CANTEEN	125A, 3P	150/5	19	
	MAIN OFFICE	63A, 4P	100/5	20	