NANDYAL MUNICIPALITY

Water Quality Monitoring Laboratory

IS:10500 :2012 Drinking Water-Specification

Water Analysis Report

SRI SHANTINIKETHAN HIGH SCHOOL, KRANTHINAGAR, NANDYAL

Dt: 01/04/2026

S.No	Characterstics	Measuring units	Requirements (Acceptable Limit)	Permissable Limit in the Absence of Alternate Sourece	Result	Remarks
1	Colour	Hazens	5	15	2.0	
2	Taste & Odour	Agreegable	Agreegable	Agreegable	Agreegable	
3	EC	M/s	< 1000		130.0	
4	Turbidity	N.T.U	1	5	0.1	
5	T.D.S	mg/L	500	2000	85.0	
6	PH		6.5-8.5	No Relaxation	6.80	
7	Total Hardness (Caco3)	mg/L	200	600	30.0	
8	Chlorides (As Cl)	mg/L	250	1000	7.0	
9	Sulphates (as So4)	mg/L	200	400	5.0	
10	Flourides (as F)	mg/L	1.0	1.5	0.2	
11	Nitrites (as No2)	mg/L	Nill	Nill	Not Detected	
12	Calcium (as c)	mg/L	75	200	10.0	
13	Magnesium (as mg)	mg/L	30	150	8.0	
14	Iron (as fe)	mg/L	0.3	No relaxation	0.01	
15	Total alkalinity	mg/L	200	600	25.0	
16	Ammonical Nitrozen (N)	mg/L	< 0.1		Not Detected	
17	Nitrate (as no3)	mg/L	45	No Relaxation	0.4	
18	Residual Chlorine	mg/L			Not Detected	
19	Coliform Bacteria 100ml (MF Method)	cfu	Nill		NILL	
20	E-coli Bacteria 100ml (MF Method)	cfu	Nill		NILL	

Remarks: The above source of water is chemically & Bacteriologically satisfactory.

CHEMIST
WQM LABORATORY
NANDYAL