

# APEX FIELD SERVICE DIVISION

## SERVICE RECORD

|                  |                                |
|------------------|--------------------------------|
| Record No.       | SR-2026-0051                   |
| Equipment Code   | PMP-0041                       |
| Service Date     | 2026-07-01                     |
| Service Type     | 180-Day Preventive Maintenance |
| Technician       | J. Alvarez (Cert #TX-4471)     |
| Next Service Due | 2026-12-28                     |

**Findings:** Mechanical seals replaced, bearings re-greased, alignment verified within tolerance. Vibration readings nominal. Unit released to service.

\_\_\_\_\_  
**Technician:** J. Alvarez

\_\_\_\_\_  
**QA Reviewer:** S. Kim