

Combustion System Covers & Enclosures

Area	Code / Standard	Requirement	Compliance Official	Governing Body
Burner Covers & Access	ASME PG-70 / NFPA 85	Burner doors, combustion ports, and sight glasses must be flame-rated and hinged for safety.	Manufacturer + Inspector	ASME, NFPA
Air/Fuel Ratio Monitoring	NFPA 85 / CSD-1	O ₂ trim systems or parallel positioning control required for large burners.	Combustion Tech	NFPA, State Code
Inspection Openings	ASME PG-58 / PG-70	Boiler must have minimum 2 inspection ports for internal cleaning and visual check.	State Boiler Inspector	ASME
Cover Sealing and Gasketing	UL 795 / ANSI Z83.4	Combustion cover gaskets must be fire-retardant and gas-tight under draft pressure.	QA Fabricator	UL, ANSI

⚠ Permit / Certificate Requirements

Type	Required For	Issued By
Boiler Installation Permit	New construction, relocation	Local Building Dept. / State Boiler Board
Certificate of Authorization (ASME Stamp)	Fabrication shop approval	ASME National Board
Repair R Stamp	Repairs & alterations	National Board Inspection Code (NBIC)
Combustion System Approval	Burner upgrades	State Fire Marshal / AHJ
Operator License / Certification	Steam plant operation	State Licensing Board (e.g., Red Seal, NYC BOE)