

SECTION 3: AUTOMATIC VALVES & ACTUATORS SOP

Purpose: Ensure that all valves and actuators respond appropriately to control signals, without mechanical delay, sticking, or overheating.

Procedures:

Test modulating steam control valve for correct signal response.

Verify actuator feedback accuracy (pneumatic or electric).

Use manual override to test fail-safe positions.

Monitor actuator temperatures for signs of electrical stress.

Lubricate per manufacturer recommendations.

Record any delays between signal and valve motion.

Notes:

Flag any actuator with delayed or inconsistent response.

Ensure all valve tags are legible and securely mounted.