

Compliance & Inspection Prep Kit

Nexum Suum | OSHA, NFPA 85, and ASME CSD-1 Readiness

1. Compliance Readiness Checklist

- Boiler logbook is updated and signed daily
- Emergency shutdown procedure is posted and accessible
- Safety valve has been tested and tagged (within 12 months)
- Burner interlocks tested and documented
- Low Water Cutoff (LWCO) blowdown performed and logged
- Stack temperature recorded and compared to baseline
- Feedwater system operating and vented correctly
- Combustion analysis completed and documented (quarterly/yearly)
- ASME stamps and pressure relief labels visible and legible
- Training records for boiler operators are current and available

2. Documentation Log Template

Date	Inspector Name	Area/Item	Notes	Initial
-----	-----	-----	-----	-----
-----	-----	-----	-----	-----
-----	-----	-----	-----	-----
-----	-----	-----	-----	-----
-----	-----	-----	-----	-----
-----	-----	-----	-----	-----
-----	-----	-----	-----	-----
-----	-----	-----	-----	-----
-----	-----	-----	-----	-----
-----	-----	-----	-----	-----

3. Visual Walk-Through Checklist

- Combustion air is unobstructed and venting correctly
- Boiler room is clean, dry, and free of combustibles
- All piping is supported and free of leaks
- Electrical panels labeled and accessible
- Emergency exits are clearly marked and free of obstructions
- Fire extinguisher is present, charged, and inspected
- Chemical storage is labeled and within approved cabinets