

Preventive Maintenance Schedule

Nexum Suum | Monthly/Quarterly Tasks – Page 2 of 8

- Inspect burner controls and flame safeguard system
- Clean and inspect flame scanner
- Test high-limit and operating pressure controls
- Check and record stack temperature trends
- Lubricate pump motors and bearings
- Check condensate return system
- Verify chemical feed pump operation
- Drain and flush mud drum or blowdown tank
- Inspect all safety valve tags and condition
- Log boiler operating efficiency data

Equipment	PM/Repair	Notes