

SECTION 12: CHILLED & CONDENSER WATER PUMP SOP

Purpose: Ensure safe and reliable operation of chilled water and condenser water pumps to maintain proper system flow, minimize energy waste, and prevent equipment failure due to improper circulation.

Daily Operational Procedures:

- Inspect pump casings, gaskets, and flange connections for visible leaks.
- Record pump suction and discharge pressure.
- Log motor amperage and compare with baseline values.
- Listen for unusual noises or vibrations.
- Verify pump rotation matches manufacturer direction.
- Confirm that VFD (if applicable) is functioning within programmed ranges.
- Inspect pressure gauges and temperature sensors for integrity.

Weekly Maintenance Tasks:

- Lubricate pump bearings per OEM guidelines.
- Check alignment between motor and pump shaft.
- Inspect pump strainers and clean if necessary.
- Verify proper valve positions upstream and downstream of pump.
- Review vibration trends and temperature logs for anomalies.

Safety Notes:

- Always isolate and lockout the pump before performing maintenance.
- Allow pump casing to cool before opening or servicing.

Applicable Standards:

- ANSI/HI Pump Standards
- NFPA 70E for electrical maintenance
- OSHA 1910 for rotating equipment safeguards