

Fire Safety (Simplex): Compliance, SOP & Optimization Guide

Purpose:

Detects, alerts, and suppresses fires to protect life, assets, and continuity of operations; ensures legal and insurance compliance

Why It's Ignored:

Systems may be assumed functional unless there's a visible fault or alarm, and tests are often postponed.

Must-Have Docs:

- Firealarm system test logs
- Sprinkler inspection reports
- Panel programming and battery logs
- Evacuation drill records

Compliance Officials:

NFPA, OSHA, AHJ(Authority Having Jurisdiction), Insurance Underwriters

PPE Required:

Gloves,safetyglasses,arc-rated gear when testing panels or working near energized fire systems

Installation Practices:

- Panelaccessmustremain clear
- Horn/strobe coverage per layout
- Tamper switches and flow alarms wired correctly
- Battery backups sized and dated

Must Checks:

- Battery voltage and expiration
- Sprinkler valve tamper seals
- Alarm panel faults or silenced events
- Pull station accessibility
- Horn/strobe functionality

Regulations & Codes:

NFPA72,NFPA25,OSHA 1910 Subpart E, Local Fire Marshal Codes