

Cooling/Chilled Systems – Ideal Temperature Ranges

System Component	Ideal Temp (°F)	High Alert Temp (°F)	Notes
Chilled Water Supply Temp	42–45	>50	Critical for HVAC system efficiency
Chilled Water Return Temp	54–58	>60	High delta-T indicates underload
Condenser Water Supply Temp	80–85	>90	Higher temp reduces chiller capacity
Condenser Water Return Temp	90–95	>100	Heat rejection to cooling tower
AHU Supply Air Temp	52–56	>60	Varies by zone setpoint
RTU Supply Air Temp	50–55	>58	Used in rooftop air systems
Direct Air Intake (DA Temp)	55–65	>70	Monitored in economizer systems

Cooling setpoints depend on ambient conditions, load demand, and equipment calibration.