

2. Test Points for Verification

Test Point	Method	Ideal Range
Stack Temperature	Digital probe after heat exchanger	350–450°F
Feedwater Temp	At DA tank or economizer outlet	190–205°F
Boiler Pressure	Pressure gauge on steam header	Per design (e.g. 80–125 psi)
Fuel Pressure	At burner inlet	Depends on gas type (e.g. 3–5 in. W.C. for NG)
Blowdown Schedule	Manual or timer-based	Daily / Every shift

3. Emergency Scenarios

Situation	Response Protocol
High pressure limit tripped	Check PRV, reset pressuretrol
LWCO fails to cut burner	Lockout burner, inspect float & probe
Flame relay trips continuously	Inspect gas valve, ignition circuit