



Below is a list of Boiler Codes, Requirements, and Compliance

Material Testing Requirements

Area	Code / Standard	Requirement	Compliance Official	Governing Body
Material Specs	ASME BPVC Section II	All boiler materials must meet certified ASME specs and documentation.	Authorized Inspector (AI)	ASME
NDT Testing	ASME BPVC Section V	Radiographic (RT), Ultrasonic (UT), Magnetic Particle (MT), and Liquid Penetrant (PT) testing are required for weld and seam integrity.	Certified NDT Level II/III	ASME, NBIC
Weld Qualification	ASME Section IX / AWS D1.1	Welders must be tested and qualified to perform pressure-retaining welds under certified procedures.	QC Manager + AI	ASME, AWS
Material Traceability	ASTM A20/A999 / NBIC Part 3	Mill test reports, heat numbers, and MTRs must be traceable and match code stamps.	Quality Control Officer	NBIC, ASME

Boiler Installation Compliance

Area	Code / Standard	Requirement	Compliance Official	Governing Body
Installation Practices	ASME BPVC Section I / NBIC Part 1	Boilers must be installed by code-certified contractors with proper anchorage, clearance, and piping.	State Boiler Inspector	ASME, NBIC, State Board
Combustion Safety System	NFPA 85	Must install flame scanners, purge logic, fuel shutoffs, and interlocks per burner capacity and fuel type.	Fire Marshal / Combustion Specialist	NFPA
Permits & Approvals	IBC / State Mechanical Code	Local permits, stamped drawings, and inspections are mandatory before startup.	Local AHJ (Authority Having Jurisdiction)	ICC, State Board
Hydrostatic Testing	ASME BPVC / NBIC	All pressure vessels must be hydro-tested at 1.5× MAWP before commissioning.	Authorized Inspector	ASME, NBIC