

2. Critical Test Points

Parameter	Test Method	Expected Range
Battery Voltage	Multimeter	12.4V–13.5V (24V systems: 24–27V)
Cranking Amps	Clamp meter	85–100% of rated amps
Coolant Temperature	Infrared or onboard	160–200°F
Fuel Pressure	Pressure gauge port	OEM-specific (usually 5–10 PSI)
Output Voltage	Test load bank or ATS	208/240/480V ± 5%

3. Emergency Conditions

Event	Immediate Action Required
Generator fails during power outage	Transfer load manually, notify vendor
Low Oil Pressure Shutdown	Check dipstick, refill and restart
Overcrank or Overspeed Alarm	Inspect controller settings and sensors
High Coolant Temp or Fan Failure	Allow cooldown, inspect radiator system