

SOP #11 – Troubleshooting Techniques for Exhaust Fans

Applies to: Roof-mounted, inline, wall-mounted, and centrifugal exhaust fans in commercial and industrial settings

1. Common Issues & Diagnostics

Symptom	Likely Cause	Recommended Action
Fan not turning on	Tripped breaker, motor failure	Reset breaker, test motor windings
Loud vibration or rattling	Loose bearings or unbalanced wheel	Inspect and tighten mounts, balance blades
Low airflow	Blocked duct, faulty dampers	Inspect duct path, test damper actuators
Overheating motor	Poor ventilation, worn windings	Ensure cooling airflow, test insulation
Intermittent operation	Faulty contactor or capacitor	Replace electrical control components