

2. Key Inspection & Test Points

Parameter	Tool/Method	Expected Range
Motor Amperage Draw	Clamp meter	Within 90–100% of FLA
Pump Cycle Frequency	Logbook or counter	<6 times/hour (typical)
Water Discharge Volume	GPM meter	Per pump spec/design
Pit Water Level Sensor	Manual test	Activates at set threshold
Check Valve Function	Visual + flow test	Prevents backflow at rest

3. Emergency Conditions

Event	Immediate Action
Pit flooding	Switch to backup pump or manual
Electrical smell or sparks	Isolate circuit, inspect wiring
System offline during rain	Activate manual override or deploy portable unit