

✓ SOP #15 – Troubleshooting Techniques for Fire Suppression Systems

Applies to: Wet pipe, dry pipe, pre-action, foam, and clean agent suppression systems (commercial, industrial)

🔧 1. Common Issues & Diagnostics

Symptom	Likely Cause	Recommended Action
Low system pressure	Leak, valve partially closed	Inspect for leaks, check control valves
Alarm sounds without fire	False trigger, sensor fault	Test sensors, check for dust/insect debris
No discharge during activation	Closed valve, pump failure, frozen pipe	Check valve position, verify pump status
Frequent false alarms	Water hammer, vibration, or air pockets	Install air release valves, re-secure lines
No power to panel	Circuit breaker trip, battery failure	Reset breaker, test backup batteries