HAW HAMBURG

Fraunhofer ISIT

Dies Academicus, HAW Hamburg 2018

Power Quality Compensation for Smart Grids by Model-based Predictive Control

Carlos Cateriano Yáñez[1,2], Kathrin Weihe[1], Georg Pangalos[2], and Gerwald Lichtenberg[1]

[1]Hamburg University of Applied Sciences, Faculty Life Sciences, Ulmenliet 20, 21033 Hamburg
[2]Fraunhofer ISIT, Application Center Power Electronics for Renewable Energy Systems, Steindamm 94, 20099 Hamburg
{carlos.caterianoyanez, kathrin.weihe, gerwald.lichtenberg}@haw-hamburg.de, georg.pangalos@isit.fraunhofer.de,

MOTIVATION

- **High order harmonics in the electrical grid introduced by switching converters need to be compensated to avoid damage and energy loss**
- **Classic active power filter (APF) controllers are capable of compensating harmonics, but are not flexible under variable load scenarios**

APPLICATION PROBLEM

A novel approach: "Linear State Signal Shaping Model Predictive Control" (LS^3MPC), to compensate harmonics using shape classes has been developed

- **Could the LS^3MPC improve the grid quality compared to a classic APF controller?**
- **Could the LS^3MPC adapt under variable load scenarios?**

CLASSIC IRP CONTROLLER



- **Clarke and p-q transformation are used**
- **A high pass filter extracts harmonics**
- **A hysteresis band controller steers the voltage source converter**

PREDICTIVE CONTROLLER

The MPC minimizes the cost function

$$J = \|\mathbf{X}(k) - \Xi(k)\|^2_{\mathbf{Q}} + \|\mathbf{U}(k)\|^2_{\mathbf{R}}.$$

Solved by constrained sparse quadratic programming (QP), with close loop behavior:



3-PHASE GRID MODEL



Active power filter in shunt configuration

LINEAR SHAPE CLASS

The shape of a sine wave is described by the homogeneous ODE

$$\frac{\mathrm{d}^2 x(t)}{\mathrm{d}t^2} + \omega^2 x(t) = 0$$

and approximated in discrete time with

$$x(k-1) + \left((\omega t_s)^2 - 2\right) x(k) + x(k+1) = 0.$$

From this difference equation the *linear shape class*[3] V is given as

$$\mathbf{V} = \begin{pmatrix} 1 & (\omega t_s)^2 - 2 & 1 \end{pmatrix} \in \mathbb{R}^{1\times 3}.$$

The state error weight matrix Q is built using V by transferring the control goal to the optimization problem

$$\min_{\mathbf{X}(k)} \left(\mathbf{V}\mathbf{X}(k)\right)^2,$$

where

$$\mathbf{X}(k) = \begin{pmatrix} x(k-1) & x(k) & x(k+1) \end{pmatrix}^\mathsf{T},$$

for all times k.

[3]Cateriano Yáñez, C., Pangalos, G., and Lichtenberg, G. (2018). An approach to linear state signal shaping by quadratic model predictive control. In *European Control Conference (ECC) 2018*

WHITE-BOX MODELING

Linear state space model of per phase

$$\mathbf{x}(k+1) = \mathbf{A}\mathbf{x}(k) + \mathbf{B}u(k) + \mathbf{E}\mathbf{d}(k)$$

where

$$\mathbf{x}(k) = \begin{pmatrix} i_f \\ i_c \end{pmatrix} \in \mathbb{R}^2 \qquad u(k) = i_{c0} \in \mathbb{R} \qquad \mathbf{d}(k) = \begin{pmatrix} v_s & i_{l0} \end{pmatrix}^\mathsf{T} \in \mathbb{R}^2$$

and

$$\mathbf{A} \in \mathbb{R}^{2\times 2}, \quad \mathbf{B} \in \mathbb{R}^{2\times 1}, \quad \mathbf{E} \in \mathbb{R}^{2\times 2}.$$

SIMULATION STUDIES

IRP APF harmonic current compensation:



LS^3MPC harmonic current compensation:



Total harmonic distortion (THD):



Results for different load scenarios:

Load scenario	*THD* (v_{PCC})		*THD* (i_f)	
	IRP	LS^3MPC	IRP	LS^3MPC
100 Ω	1.07%	0.01%	6.68%	0.18%
9 Ω	0.75%	0.02%	2.72%	0.11%
2 Ω	0.85%	0.07%	2.56%	0.05%

CONCLUSION

- **The LS^3MPC can successfully improve the THD compensation of an APF**
- **Classic IRP rely on high pass filter design for a given load scenario, while LS^3MPC can inherently adapt to a wider variety**
- **Current research on LS^3MPC focuses on enabling reactive power compensation**