

# AHJ Plan Check Comments (Raw) (Mock)

Received: 2026-02-06 | Application: EL-2026-01472 (mock)

EV Charging Site Project — Phase 5 Inputs (MOCK)

This document represents mock AHJ plan-check comments as downloaded from the portal. Replace with the actual PDF issued by the AHJ.

## Comments (mock):

- C-01: E-001 one-line — clarify EMS method, monitoring point, and fail-safe behavior; cite code basis.
- C-02: E-001 one-line — provide available fault current basis and confirm minimum AIC for OCPDs.
- C-03: E-005 notes — add explicit EVSE continuous-load factor statement and labeling requirements.
- C-04: E-002/E-004 — standardize EV subpanel designation across plan + schedules (EVSP-1).

MOCK / EXAMPLE ONLY