

Comment Response Letter (Rev 1) (Mock)

Date: 2026-02-12 | Application: EL-2026-01472 (mock)

EV Charging Site Project — Phase 5 Outputs (MOCK)

This letter provides point-by-point responses to each AHJ plan-check comment and references where updates were made in the revised set (mock).

Responses (mock):

C-01: Added EMS narrative, monitoring point label, and fail-safe note on sheet E-001. See Rev 1 cover notes.

C-02: Added fault current basis and minimum AIC statement on sheet E-001. See Rev 1 cover notes.

C-03: Expanded notes on sheet E-005 to explicitly state continuous-load factor and labeling requirements.

C-04: Standardized EV subpanel designation to EVSP-1 across E-002 and E-004.

MOCK / EXAMPLE ONLY

Signed (mock): Priya Shah, PE _____ Date: 2026-02-12