



E-005 — Electrical Notes & Code Sheet (Mock)

P3.5
EV Charging Site Project — Phase 3 Outputs (MOCK)

GENERAL NOTES (electrical-only, mock)

- 1. Applicable code basis: 2022 California Electrical Code (CEC) (mock). Verify AHJ amendments.
- 2. EVSE loads treated as continuous; size OCPD and conductors accordingly (125% basis).
- 3. EMS/load management (if used) shall be listed and configured to enforce aggregate cap (mock: 250A).
- 4. Provide identification labeling for EV equipment and circuits; coordinate with panel schedules.
- 5. Provide grounding and bonding per code; bond raceways as required.
- 6. Verify available fault current and minimum AIC ratings in final stamped set.

SYMBOLS / LEGEND (mock)

-  EVSE location marker
-  EMS / Load management annotation

PROJECT (mock): EV Charging Site Project	SHEET: E-005	ISSUED FOR:
SHEET TITLE: Electrical Notes & Code Sheet	REV: 0	UNSTAMPED
ADDRESS: Place (Palo Alto, CA) (mock)	DATE: 2026-01-26	(electrical-only)