

EMS Configuration Summary — As Installed (Mock)

Export date: 2026-03-21 (mock) | Setpoint: 250A cap
EV Charging Site Project — Phase 7 Outputs (MOCK)

This document represents a mock EMS configuration export suitable for inspection support and closeout records.
Replace with actual vendor export and listing evidence.

Configuration fields (mock):

Aggregate cap setpoint:	250A
Monitoring point:	EV feeder CTs at EVSP-1 feeder
Fail-safe mode:	Cap enforced on comms loss
Ports managed:	8
Export hash (mock):	CFG-20260321-250A-REV1

MOCK / EXAMPLE ONLY