

E-004 — Updated Panel Schedules (MDP + EVSP-1) (Mock)

P3.4
EV Charging Site Project — Phase 3 Outputs (MOCK)

MDP — Updated (excerpt) (mock)

Slot	Breaker	Load	Notes
40/42/44	350A 3P	EVSP-1 feeder	Managed to 250A (mock)
17	200A 3P	SUBP-1	Existing
57	Spare	Spare/Space	Available 3-pole

EVSP-1 — New (excerpt) (mock)

Slot	Breaker	Load	Notes
1	40A 3P	EVSE-01	32A cont (mock)
2	40A 3P	EVSE-02	32A cont (mock)
3	40A 3P	EVSE-03	32A cont (mock)
4	40A 3P	EVSE-04	32A cont (mock)
5	40A 3P	EVSE-05	32A cont (mock)
6	40A 3P	EVSE-06	32A cont (mock)
7	40A 3P	EVSE-07	32A cont (mock)
8	40A 3P	EVSE-08	32A cont (mock)

NOTE: schedules are mock excerpts; full schedules included per P1 evidence in real project.

PROJECT (mock): EV Charging Site Project	SHEET: E-004	ISSUED FOR:
SHEET TITLE: Panel Schedules (MDP + EVSP-1)	REV: 0	UNSTAMPED
ADDRESS: Place (Palo Alto, CA) (mock)	DATE: 2026-01-26	(electrical-only)