

Sovereign-Core Test Document A

Project Code: SC-4821

Inspection Site: Reactor Unit 7

Inspection Date: 18 August 2026

Maximum Recorded Temperature: 418.6 °C

Minimum Recorded Pressure: 11.4 bar

Lead Engineer: Arjun Mehta

Valve V-204 failed the leakage inspection.

Recommended Action:

Replace the stem seal of Valve V-204 before the next pressure cycle.

Risk Level: HIGH