



GOVERNMENT OF ARUNACHAL PRADESH
OFFICE OF THE ASSISTANT ENGINEER
PUBLIC HEALTH ENGINEERING & WATER SUPPLY
SUB-DIVISION ::: MIAO

AE
PHESD Miao

No. AE/PHEM/Estt./2025-26/386




Dated Miao, the 20th Sept. 2026

HEALTH & SANITATION CERTIFICATE

This is to certified that the health and sanitation facilities of Government Secondary School, Vijaynagar have been inspected by the competent authority, subject to the observation and verification recorded below: -

Name of Institution: -	Government Secondary School ,Vijaynagr.
Location: -	Vijaynagar, Changlang, Arunachal Pradesh
Inspection Date: -	18/09/2026
Toilet Facilities: -	Available
Separate facilities for Boys & Girls: -	Available
Hand-Washing Facilities: -	Available
Solid Waste Management: -	To be improved
Cleanliness & Hygiene: -	Satisfactory
Drainage/ Wastewater Management: -	To be improved
General Sanitation Observation: -	Found in good condition

Certificate status: The certificate may be issued only after physical inspection and verification by the competent authority. Any deficiencies identified during inspection should be rectified within the period prescribed by the authority.


Assistant Engineer,
PHE & WS Sub-Division
Miao
Assistant Engineer
PHE & WS Sub-Division
Miao

WATER TESTING LABORATORY REPORT

Name of Village/Town:- Vijaynagar Headquarter

Habitation:- Govt. Sec. School, Vijaynagar HQ

Type of Source:- Gravity

Date of Testing :- 06-10-2026

Physical Parameters

Sl	Parameter	Result	Unit	Limit
1	Colour	Acceptable	HU	Acceptable
2	Turbidity	0.90	NTU	≤5

Chemical Parameters

Sl	Parameter	Result	Unit	Limit
1	pH	8.00	pH	6.5-8.5
2	TDS		mg/L	500
3	Hardness	75	mg/L	200
4	Alkalinity	100	mg/L	200
5	Calcium		mg/L	75
6	Magnesium		mg/L	30
7	Chloride	8	mg/L	250
8	Sulphate	3	mg/L	200
9	Nitrate	0.32	mg/L	45
10	Iron	0.00	mg/L	0.3

Bacteriological Parameters

Sl	Parameter	Result	Unit	Limit
1	Bacteria	Negative	MPN/100mL	Absent

Remarks

The tested water sample does not exhibits any contamination for the following parameters, rendering it fit for potable use


Lab Assistant
PHE & WS Sub-Division
Miao