\5515024830 hizmet nolu tesisata aittir.xml:

Test Device:

Serial Number:

EG519F (V0)

Date/Time:

02/25/2025 10:39:45

Overall assessment: n/a

Test Cards Overview:

Test Card	Туре	Date/Time	Results	Assessment	Overload
447484	CTRatio	02/25/2025 10:39:14	yes	n/a	no
447417	CTRatio	02/25/2025 10:39:23	yes	n/a	no
447496	CTRatio	02/25/2025 10:39:37	yes	n/a	no

Test Cards:

447484:

Card Type:

CTRatio

Date/Time:

02/25/2025 10:39:14

Overload:

Assessment: n/a

2 5 -02- 2025 66 / 30000 / 200000 / 2000000

Tarihinde yapılan kontrolde

Tast Sanger Uygundur."

2 5 -02- 2025

4 / /

Tarihinde yapılan kontrolde

Tost Senuou Uveundur."

" / /

Tarihinde yapılan kontrolde

"Tast Sonucu Uvgundur."

Range:

Nominal values:

AC 800A

I prim.: 400 A

I sec .:

5.000 A

Frequency: I test:

50.00 Hz 400.0 A

Automatic:

ves

Results:

I prim.:

401.04 A

I sec .: Ratio:

5.02468 A 0.30° 400 A:5.0117 A 0.23 %

Polarity:

OK

447417:

CTRatio Card Type:

Date/Time: 02/25/2025 10:39:23

Overload:

Assessment: n/a

Range:

Nominal values:

I prim.:

400 A 5 000 A

I sec .: Frequency:

50.00 Hz 400.0 A

AC 800A

I test: Automatic:

ves

Results: I prim.:

399.92 A 5.01336 A

0.00 ° 0.27° 0.29 %

> 0.00° 0.28°

0.28 %

0.00°

I sec.: Ratio:

400 A:5.0144 A OK

Polarity: 447496:

Card Type:

CTRatio

Date/Time:

02/25/2025 10:39:37

AC 800A

400 A

400.0 A

yes

Overload: no

Assessment: n/a

Range:

Nominal values:

I prim.:

5.000 A I sec .: 50.00 Hz

Frequency: I test:

Automatic: Results:

I prim.:

I sec .:

399.91 A 5.01284 A

Ratio:

400 A:5.0140 A OK Polarity:

2 5 -02- 2025