NFRC Product Certification Authorization Report

Manufacturer: VELUX
Street: P.O. Box 5001
City/State/Zip: Greenwood, SC 29648-5001
Print Date: 11/10/2022

Product Series: TCC / TCR / TGC / TGR / THR / TMC / TMR
Product Type: TDDY
Air Leakage:

Simulation Lab: SATI
Sim. Report #: I1927.09
Sim. Report Date: 02/22/2018
Test Date: 01/01/1970

Initial Cert. Date: 05/06/2014
Re-Certification Date: 03/08/2018
Revised Date: 04/12/2019
Expiration Date: 02/26/2023

CPD Number: VEL-N-26 — **IA: Window and Door Manufacturers Association (WDMA)**

Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.
	00011-00001	[TCC 014 or TGC 014 or TMC 014] + [0000 or 1000] With Diffuser TTC 014 000* (*denotes 0 or 2 or 3) + ZTC 014 0401US	OT/N	4		19.75,0.280,24 .00	N	Fill 1: Air(100) , Fill 2: Air(100) , Fill 3: Air(100)	N		CL	0.51	0.34	0.36	
	00012-00001	[TCC 014 or TGC 014 or TMC 014] + [0000 or 1000] With Diffuser TTC 014 000* (*denotes 0 or 2 or 3)	OT/N	2		43.38	N	Fill 1: Air(100)	N		CL	2.00	0.61	0.52	
	00013-00001	[TCC 014 or TGC 014 or TMC 014] + [0000 or 1000] With Diffuser TOC 014 000* (*denotes 0 or 2 or 3) + ZTC 014 0401US	OT/N	4		19.75,0.280,24 .00	N	Fill 1: Air(100) , Fill 2: Air(100) , Fill 3: Air(100)	N		CL	0.50	0.33	0.33	
	00014-00001	[TCC 014 or TGC 014 or TMC 014] + [0000 or 1000] With Diffuser TOC 014 000* (*denotes 0 or 2 or 3)	OT/N	2		43.38	N	Fill 1: Air(100)	N		CL	1.68	0.47	0.45	