
Red tech official for radiographer

# **30 MCQs:** Quality Control in Radiography

### 1. What is the acceptable limit for collimator misalignment in quality control testing?

- A. 1% of SID
- B. 2% of SID
- C. 5% of SID
- D. 10% of SID




#### Correct answer: B. 2% of SID

According to quality control guidelines, collimator alignment must not exceed 2% of the Source-to-Image Distance (SID).



#### 2. The spinning top test is used to evaluate:

- A. Focal spot size
- B. Timer accuracy
- C. Beam alignment
- D. kVp calibration



Correct answer: : B. Timer accuracy

A spinning top test is used for single-phase generators to check timer accuracy through the number of dots produced on the image.



#### 3. Which of the following QC tests is performed daily?

- A. Focal spot size measurement
- B. Filtration test
- C. Processor sensitometry
- D. Reproducibility of exposure

The sensitometer is an instrument designed to expose a reproducible, uniform, optical stepwedge pattern onto a film

| Selection | Selecti

#### Correct answer: C. Processor sensitometry

Processor sensitometry is a daily QC check that ensures consistent film development using a step wedge or sensitometer.


### 4. Half-value layer (HVL) testing is essential to

#### evaluate:

- A. Exposure reproducibility
- B. Beam filtration
- C. Image density
- D. Grid performance

#### Correct answer: B. Beam filtration

HVL measures the thickness of a material that reduces the x-ray beam intensity by half and is used to assess filtration adequacy.





5. What is the tolerance limit for reproducibility of

exposure?

A. ±2%


B. ±5%

C. ±10%

D. ±20%

Correct answer: B. ±5%

Exposure reproducibility should be within ±5% for the same technical settings on repeated exposures.



- 6. Which test is used to evaluate focal spot size?
- A. Pinhole camera
- B. Star test pattern
- C. Slit camera
- D. All of the above

Correct answer: D. All of the above



### 7. The kVp accuracy test tolerance is typically within:


Correct answer: B. ±5%

kVp accuracy should be within ±5% of the indicated value for QC compliance.



#### 8. Which device is used to evaluate beam alignment?

- A. Step wedge
- B. Coin test
- C. Beam alignment test tool
- D. Line pair phantom



Correct answer: C. Beam alignment test tool
Beam alignment test tools check congruence between the light field and radiation field.

### 9. An increase in base + fog value on a sensitometric strip indicates:


- A. Poor contrast
- B. Increased developer activity
- C. Fogged film
- D. High exposure latitude

Correct answer: C. Fogged film

A rise in base + fog means unintended film darkening, usually due to improper handling or processing.

#### 10. Line pair phantom is used to assess:

- A. Beam quality
- B. Spatial resolution
- C. Density reproducibility
- D. Timer accuracy



Correct answer: B. Spatial resolution
Line pair resolution phantoms assess the ability of the system to

display small, high-contrast objects.

## 11. Which QC test is done weekly for film-screen systems?

- A. Film-screen contact test
- B. Timer accuracy
- C. Focal spot measurement
- D. kVp calibration

Correct answer: A. Film-screen contact test

A wire mesh or screen contact test is conducted weekly to check for screen deterioration or warping.

#### 12. The densitometer in QC is used for measuring:

- A. Radiation dose
- B. Light field accuracy
- C. Optical density
- D. mAs output

Correct answer: C. Optical density
A densitometer measures optical density on processed films and is vital in processor QC.

### 13. Which is a key indicator for processing system quality?

- A. Contrast index
- B. Speed index
- C. Base + fog
- D. All of the above

Correct answer: D. All of the above

These three parameters reflect chemical and mechanical efficiency in film processors.



#### 14. To test exposure linearity, one evaluates:

- A. kVp vs. density
- B. mAs vs. output
- C. SID vs. magnification
- D. Filtration vs. HVL

Correct answer: B. mAs vs. output Exposure linearity ensures that output increases proportionally with mAs changes.



#### 15. Grid uniformity testing evaluates:

- A. Grid lines
- B. Field size
- C. Exposure index
- D. Beam centering

Correct answer: A. Grid lines

Uniformity testing ensures consistent exposure across the grid without artifacts or cutoff.

#### 16. A sudden drop in contrast index may indicate:

- A. Overexposure
- B. Developer exhaustion
- C. Misalignment
- D. Filter failure

Correct answer: B. Developer exhaustion

Poor development chemistry can reduce contrast in processed films.

### 17. Acceptable variance in optical density between exposures in reproducibility testing is:

A. 0.02

B. 0.05

C. 0.10

D. 0.20

Correct answer: B. 0.05

OD differences should not exceed 0.05 to pass reproducibility standards.

### 18. For digital systems, QC evaluation of bit depth is related to:

- A. Matrix size
- B. Noise
- C. Contrast resolution
- D. Field uniformity

Correct answer: C. Contrast resolution
Bit depth affects grayscale and is directly related to contrast resolution.

#### 19. The primary goal of quality control is to:

- A. Reduce patient complaints
- B. Increase radiologist performance
- C. Ensure consistent image quality
- D. Increase exposure times

Correct answer: C. Ensure consistent image quality QC aims to optimize diagnostic image quality while ensuring equipment efficiency and safety.

#### 20. The term 'sensitometry' is associated with:

- A. Measuring exposure index
- B. Evaluating film response
- C. Measuring filtration
- D. Testing beam centering

Correct answer: B. Evaluating film response Sensitometry evaluates film response to exposure and development processes.



### 21. Which of the following is tested using a step wedge?

- A. Spatial resolution
- B. Contrast
- C. HVL
- D. Penumbra

Correct answer: B. Contrast
Step wedge helps assess film contrast through a range of exposures.



#### 22. The test for mA linearity checks that:

- A. Output is consistent with varying time
- B. Output is proportional to mA
- C. Exposure time is constant
- D. SID is accurate

Correct answer: B. Output is proportional to mA Linearity testing ensures the tube output changes linearly with mA settings.



### 23. An automatic exposure control (AEC) QC test involves:

- A. Varying focal spots
- B. Changing patient thickness
- C. Using step wedges
- D. Measuring dose rate

Correct answer: B. Changing patient thickness AEC response to different phantom thicknesses is evaluated during QC checks.

### 24. In a digital system, the photodiode used in detectors is typically made of:

- A. Tungsten
- B. Selenium
- C. Silicon
- D. Cesium

Correct answer: C. Silicon Amorphous silicon is widely used in flat-panel detectors for digital radiography QC.

### 25. Which test is used to evaluate viewbox luminance?

- A. Densitometer
- B. Photometer
- C. Ion chamber
- D. Dosimeter

Correct answer: B. Photometer

A photometer measures the brightness of the viewbox to ensure proper film evaluation.

### 26. In digital imaging, "ghosting artifacts" may occur due to:

- A. Inadequate erasure of the imaging plate
- B. Dirty grid
- C. Miscalibrated collimator
- D. Poor darkroom ventilation

Correct answer: A. Inadequate erasure of the imaging plate

In CR systems, residual images can result from incomplete erasure of imaging plates.

#### 27. A "flat-field" test in digital imaging checks:

- A. Patient positioning
- B. Uniform detector response
- C. Beam collimation
- D. Exposure index accuracy

Correct answer: B. Uniform detector response Flat-field test detects pixel dropouts and nonuniformity across the detector surface.

#### 28. Poor screen-film contact will lead to:

- A. Quantum mottle
- B. Geometric distortion
- C. Loss of sharpness
- D. Grid artifacts

Correct answer: C. Loss of sharpness Poor contact allows blurring, decreasing spatial resolution.



### 29. The acceptable level of leakage radiation from the x-ray tube housing is:

- A. <0.1 mGy/h at 1 m
- B. <1 mGy/h at 1 m
- C. < 0.5 mGy/h at 1 m
- D. <0.25 mGy/h at 1 m

Correct answer: B. <1 mGy/h at 1 m Regulatory standards limit tube leakage to under 1 mGy/hour at 1 meter.

#### 30. Quality assurance includes:

- A. Quality control only
- B. Staff training, audits, QC
- C. Only equipment testing
- D. Exposure measurements

Correct answer: B. Staff training, audits, QC QA is broader, encompassing QC, personnel education, policy, audits, and documentation.