

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Afton

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	46	20	mg/l Pt/Co	0	< 2	3.41	10
Turbidity	46	4	NTU	0	< 0.30	0.49	2.50
Odour	46	0	Dilution number	0	0	0	0
Taste	46	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	46	9.5	pH units	0	7.30	7.63	8.40
Nitrite	46	0.5	mgNO ₂ /l	2.17	< 0.02	0.07	0.53
Ammonium (total)	46	0.5	mg/l as NH ₄	0	< 0.04	0.25	0.42
Total organic carbon	4		mgC/l	0	1.20	2	2.50
Aluminium	46	200	µgAl/l	0	< 8	18.80	65
Iron	46	200	µgFe/l	10.87	< 6	89.20	488
Manganese	46	50	µgMn/l	0	< 2	6.02	24
Lead	46	10	µgPb/l	2.17	< 0.30	0.66	10.90
Coliform Bacteria (Total coliforms)	96	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	96	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	46	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	46	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	96		CFU/ml	0	0	0.57	18
Residual Disinfectant - Free	96		mg/l	0	< 0.04	0.05	0.09
Residual Disinfectant - Total	96		mg/l	0	< 0.04	0.78	1.20
Conductivity	46	2500	µS/cm	0	99	112.30	129

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Afton

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Chloride	46	250	mgCl/l	0	5	8.07	12
Tetrachloro methane	4	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	4	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	4	100	µg/l	0	7.80	21.70	36.90
Chlorite	46	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	4	60	µg/l	0	9.70	19.70	30.90
1_2 Dichloroethane	4	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	4	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	46	10	µgBrO3/l	0	< 0.90	0.91	1.30
Microcystin LR	4	1	µg/l	0	< 0.05	< 0.05	< 0.05
Sulphate	4	250	mgSO4/l	0	19	29.43	37.90
Sodium	4	200	mgNa/l	0	2.90	4.35	6.40
Nitrate	4	50	mgNO3/l	0	< 0.50	0.59	0.76
Nitrite/Nitrate formula	4		Unitless	0	0	0.02	0.04
Copper	4	2	mgCu/l	0	< 0.00	0.01	0.02
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	< 0.20	0.25	0.30
Cadmium	4	5	µgCd/l	0	< 0.02	0.02	0.03
Cyanide	4	50	µgCN/l	0	1	2.75	5
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Afton

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	1.30	2.80
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Chlorate	4	0.25	mg/l	0	< 0.01	0.04	0.14
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13